

Repository Istituzionale dei Prodotti della Ricerca del Politecnico di Bari

ANTAEUS Project for the Regional Vulnerability Assessment of the Current Building Stock in Historical Centers

This is a post print of the following article

Original Citation:

ANTAEUS Project for the Regional Vulnerability Assessment of the Current Building Stock in Historical Centers / Uva, Giuseppina; Casolo, S; Sanjust, C. A.; Mezzina, M.. - In: INTERNATIONAL JOURNAL OF ARCHITECTURAL HERITAGE. - ISSN 1558-3058. - STAMPA. - 10:1(2016), pp. 20-43. [10.1080/15583058.2014.935983]

Availability: This version is available at http://hdl.handle.net/11589/5781 since: 2022-06-21

Published version DOI:10.1080/15583058.2014.935983

Terms of use:

(Article begins on next page)

02 May 2024



The ANTAEUS Project for the regional vulnerability assessment of the current building stock in historical centres

Journal:	International Journal of Architectural Heritage	
Manuscript ID:	Draft	
Manuscript Type:	Original Article	
Date Submitted by the Author:	n/a	
Complete List of Authors:	Uva, Giuseppina; Politecnico di Bari, DICATECh Sanjust, Carlo Alberto; Politecnico di Milano, ABC Casolo, Siro; Politecnico di Milano, ABC Mezzina, Mauro; Politecnico di Bari, DICATECh	
Keywords:	Seismic vulnerability assessment, Historical centres preservation, Vulnerability index method, Building inventory, Field survey form, GIS mapping	

SCHOLARONE[™] Manuscripts

The ANTAEUS Project for the regional vulnerability assessment of

the current building stock in historical centres

G. Uva¹, C.A. Sanjust², S. Casolo², M. Mezzina¹

Abstract This paper presents a methodology for the seismic vulnerability assessment of current buildings, suitable for the study of historical centres at the regional scale. The applicability is demonstrated with reference to four case studies: the historical centre of the city of Foggia (Italy) and three other small towns of this province, for a total of 4519 housing units. Field data were collected by several teams of technicians by means of a survey form, provided in electronic format. The subsequent data processing and drawing of vulnerability maps was performed using GIS. The collected data were used also for the validation of the algorithm, by comparing the results with those of the GNDT methodology, which is widely adopted in Italy. The results of the research study and the application showed some critical points, related to the poor nature of the information collected and to the reliability of the final results. These issues are analysed and discussed, proposing a strategy for improving the methodology.

Keywords: Seismic vulnerability assessment, Historical centres preservation, Vulnerability

index method, Building inventory, Field survey form, GIS mapping.

Introduction

The seismic vulnerability assessment at the regional scale is a crucial element of seismic risk prevention and mitigation strategies, which are the challenges of the last decades. Many recent earthquakes have shown that in many countries all over the world the existing building stock is severely at risk, and in many cases, the policies adopted have been inadequate, leaving space to uncoordinated actions, with ineffective or even detrimental effects (D'Ayala and Benzoni 2012).

In the past twenty years, two different approaches for the seismic vulnerability assessment at the regional scale have been developed, generally known as 1^{st} level and 2^{nd} level approach:

¹ G. Uva Politecnico di Bari -- Tel.: +39-081-5963832 -- <u>g.uva@poliba.it</u>

M. Mezzina Politecnico di Bari -- m.mezzina@poliba.it

² C.A. Sanjust Politecnico di Milano -- Tel.: +39-02-2399-4296 -- <u>carlo.sanjust@polimi.it</u>

S. Casolo Politecnico di Milano -- Tel.: +39-02-2399-4356 -- siro.casolo@polimi.it

1st level procedures are aimed at a preliminary evaluation based on few empirical parameters. Input data are gathered by simple and quick visual inspections (GNDT 1994, 2000, 2001; Benedetti and Petrini 1984; Corsanego 1993; Goretti and Di Pasquale 2002; Zuccaro 1996; GLABEC 2001; Dolce et al 2003; Lagomarsino and Giovinazzi 2006; Calvi et al 2006; Rota et al 2008; Rota et al 2011).

2nd level procedures include more detailed elements about structural characteristics and damage modes. They always operate at a territorial or urban scale, but are usually devoted to a specific building type (churches, palaces, bridges...) and collect more detailed information (Casolo et al 2000; Petrini et al 1999; GNDT 1999a, 1999b; GLABEC 2001; Lagomarsino and Podestà 2004a,b; Casolo and Uva 2011; Mezzina et

al 2012; Lagomarsino 2012; Raffaele et al 2013; Casolo et al 2013; Mansour et al 2013)

Recently, multi-level approaches have been introduced (FEMA 2012; RISK-UE 2004; Cosenza et al 2005), which provide different levels of analysis. A progressive and rational increase of the amount of information and accuracy of the results is performed, according to strategic priorities and available resources. A well acknowledged method, in this field, is the HAZUS methodology, which is based on a semi-quantitative approach: the seismic demand (expressed in terms of the Acceleration Displacement Response Spectrum - ADRS), is compared with the structural capacity, expressed by an equivalent acceleration-displacement curve obtained from an incremental non-linear pushover analysis. It is organized into multiple levels, from the regional scale up to the scale of the individual building. All the results provided at a large scale (both regional and urban) have only a relative validity within the considered set of buildings (which shall be sufficiently homogeneous with regard to the typological, structural and constructive aspects). It is possible to sort the buildings by vulnerability/risk level, in order to budget the different intervention options and support the definition of mid and long-term mitigation strategies. Instead, a direct comparison among results relative to very different

Page 3 of 75

International Journal of Architectural Heritage

geographic areas can be misleading. Finally, the actual safety level of an individual building can be obtained by means of a complete structural analysis of the building, that is sometimes referred to as the 3rd level analysis (Lagomarsino and Giovinazzi 2006; Casolo and Sanjust 2009; Milani et al 2011; Casolo et al 2013).

2 The adopted methodology

This paper presents the research study ANTAEUS, concerning the regional seismic vulnerability assessment of the building stock in the historical centres of the Province of Foggia (Puglia, Southern Italy). It is a module of a wider research project funded by Regione Puglia and managed by Autorità di Bacino della Puglia (Basin Authority of Puglia), in cooperation with a number of public institutions (Department Dicatech of the University "Politecnico di Bari", Municipality of Foggia, Administration of the Province of Foggia). The general regional project involves various types of natural risks: earthquake, floods, geo-morphological instabilities, landslides, which have been studied by different research groups, and then integrated within a Geographic Information System (Castorani et al 2011). The seismic module ANTAEUS has the objective of providing the local authorities with methodologies and tools for the quick vulnerability assessment of the historical centres in the territory by means of empirical methods, which in Italy represent the most widely used approach. The idea is that each municipality can gradually plan and implement the procedures for collecting the data and sensitive information required for the risk assessment, before an earthquake occurs. The seismic vulnerability and risk assessment is organised according to a multi-level scheme, of which the first one is here discussed, whereas some details about the other modules of the project can be found in the literature (Raffaele et al 2013).

The research scope has been limited to historical centres, in which there are large sets of buildings with similar structural characteristics (masonry walls, timber roof and floors...), and it

seems reasonable to adopt a 2nd level procedure. Nevertheless, there are some drawbacks:

- existing 2nd level forms are dedicated to specific structural typologies (for instance, the GNDT form is restricted to masonry buildings), whereas in many Italian centres there is also a significant amount of RC buildings.
- 2. The quantity of data to be collected is extensive and requires the employment of specialised and trained technicians. The survey involves, in general, the inspection of the interior of the building (which is often not accessible, since many Italian historical centres are only inhabited during holiday periods).

1st level procedures are a possible alternative, widely used for the vulnerability assessment at a large scale (Dolce, 2003), however when managing a relatively small sample of buildings the use of such a basic level of investigation could be poorly significant. Therefore, we have decided to propose a specific survey form and an algorithm for the evaluation of the vulnerability index (ANTAEUS) whose results are directly comparable with those of GNDT (Italian Group for the Defence against Earthquakes) methodology (GNDT 1994; Ferrini et al 2003), which is the Italian reference for the seismic vulnerability assessment. Since GNDT vulnerability index method is aimed at masonry buildings, an extension to RC structures has been suggested. The proposed procedure is described in the first part of the paper (Sections 3, 4, 5).

The second part of the paper is focused on the extensive application on four representative case studies (the historical centres of *Foggia, Carlantino, Vico del Gargano* and *Sant'Agata di Puglia*). These towns are different from each other for extension, number of inhabitants, history, constructive and typological characters, geo-morphological condition. Their choice was made in order to provide a representative picture about the 64 municipalities of the Province of Foggia. In general, they might be considered a valid model for many historical centres of Southern Italy. In the selected towns, groups of technicians (architects and engineers) have assessed 4519 buildings by means of rapid visual inspections, filling in the ANTAEUS vulnerability form. The field

survey provided a large database for the application and calibration of the approach. In particular, we performed a critical assessment of the quality, representativeness and reliability of input data, vulnerability parameters and results. The procedure illustrated in Sections 3-5 is based on well-established methods of indirect vulnerability assessment, introducing specific variations in the number and type of input data, in the number and definition of vulnerability parameters, and in the final algorithm. Side by side with the application of the survey form on the selected case studies, it was necessary to check the performance of the procedure, verifying the results obtained on a reference benchmark. In particular, in Section 7, a detailed analysis of a significant sample of 140 buildings (73 in the Municipality of Foggia; 67 equally distributed among the other case studies) was made. Results were systematically compared with two different vulnerability index methods: the version applied in Italy by GNDT (Benedetti and Petrini 1984; GNDT 1994); the version modified by Tuscany Region (Ferrini et al 2003). The procedure described in Sections 4-5 is the final version, obtained after the verification and calibration process presented in Section 7. Then, the data about the 4519 buildings were implemented in a GIS, plotting different maps representing the spatial distribution of the most significant parameters. In particular, the objective was to analyse in detail the quality of the data and the uncertainty factors related to the phase of data retrieval (quickness and coarseness of rapid visual inspections; possible incompleteness of information; subjectivity of data reading/interpretation; inhomogeneity in the level of training and experience of the operators). A detailed reliability analysis of the results was performed, in order to identify possible critical points, propose a sanitization of the database, and optimize the performance of the procedure (Section 8). Throughout all this phase, there was a constant interaction between the scientific board and the coordinators of the survey teams, in order to intervene promptly on the survey form and solving operational difficulties.

2.1 The application context

Puglia was traditionally considered a low seismic risk region, even in the Northern areas (Province of Foggia) that were affected in the past by seismic events: it is worth remembering the destructive Earthquake of 1731, which caused many damages in the city of Foggia (Mezzina 2011). Before 1962, none of the municipalities was classified as seismic. In year 1962, a few municipalities in Gargano and Dauni Mountains were classified, whereas only since June 3, 1981, the seismic hazard in the whole Province of Foggia was acknowledged as medium-high (Figure 1). Therefore, the regional authorities have faced the issue of the seismic risk mitigation at the regional scale much later than other Italian regions. After the Earthquake of Molise and Puglia of 31 October 2002 (Regione Molise 2002), the problem of the territorial inventory of the building stock and appraisal of its level of vulnerability became urgent, and a number of were initiated, among which the pilot research study ANTAEUS.

2.2 The algorithm for the calculation of the vulnerability index

The vulnerability index I.V. is calculated for each building after the filling of a rapid field survey form that contains a number of vulnerability-sensitive information (e.g. materials, constructive elements and details, plan and elevation configuration, type of foundation...). These data are combined into a set of seismic vulnerability parameters, and associated to a vulnerability class (from the lowest - A to the highest - D). The class assigned to each parameter is then translated into a numerical score, according to a conventional pre-defined scale. After assigning the vulnerability class, the score can be modified to take into account for special situations or secondary factors (for instance, the presence of seismic retrofitting or improvement can modify the vulnerability class assigned on the base of the year of construction of the building). The modifiers adopted in the algorithm are listed in the manual (ANTAEUS Project 2011). Finally, the combination of the scores, weighted by proper coefficients, provides the overall vulnerability

index

3 Description of the ANTAEUS form

The ANTAEUS form is divided into three parts (see Appendix): the first one contains the general data of the building; the second part is the proper vulnerability assessment form (Sections [3.1], [4.1], [4.2]); the third is devoted to the assessment of the actual damage of the building. For each independent structural unit, one form has to be filled in. In the case of more units with structural continuity, we will speak of a *structural aggregate*, and the position of the unit within the aggregate will represent a specific vulnerability factor.

3.1 General data

This part (Sections [1.1][1.2][2.1]) is aimed at clearly identifying the geographical position of the building and defining the general characteristics of the structure by means of pictures and a few sketches in plan.

3.2 Vulnerability data

This part is divided into 3 sections: a general one (Common data - [3.1]), suitable for all types of buildings, and two special sections respectively aimed at masonry building [4.1] and reinforced concrete buildings [4.2]. The attention is focused on the elements that are useful for evaluating the role of the different structural elements on the global seismic behaviour of the building, as briefly described below (for a detailed explanation, see the form reported in the Appendix and the Manual - Project ANTAEUS, 2011).

Common data

- Geometric data [3.1.1]
- *Morphology of the structural unit [3.1.2]*: position of the unit within an aggregate of adjacent units, irregularity in-plan, changes and discontinuities in the elevation of the

building, presence of staggered floors, presence of loggias or porches, irregularities in the distribution of infill panels (open ground story, short columns...).

- *Topographic factors [3.1.3]*: topographical irregularities that may cause local seismic amplification phenomena.
- *Maintenance [3.1.4]:* presence of damages or deterioration of different structural/non-structural parts.
- *Modifications after construction [3.1.5]*: changes undergone by the building at a later stage after its construction (addition of storeys, enlargements, seismic retrofitting...).
- *Non-structural elements [3.1.6]*: vulnerability of non-structural elements that may induce damage to property or cause injuries in the event of collapse.
- *Exposure [3.1.7]*: quantity and quality of elements at risk, number of people possibly involved.

Masonry buildings [4.1]

- *Vertical structures [4.1.1]*: prevalent type of vertical structures (multiple-choice table is given in the manual), percentage of continuous bearing walls on the main façade (in elevation), area in-plan of the vertical structures (at the ground floor).
- *Floors [4.1.2]*: prevalent type of horizontal structures (multiple-choice table is given in the manual), possible presence of stiffening structures.
- *Roof [4.1.3]*: typology (thrusting or non-thrusting), inclination of the pitch, presence of reinforced concrete ring beams or steel ties under the roof eaves.
- Age of the building [4.1.4]: This entry takes into account the influence of the age of construction on the seismic vulnerability of the building. In order to easily compare these data with those derived from the census database (ISTAT Census of population and buildings) and to take into account the evolution of seismic codes in Italy, buildings are sorted into pre-defined age classes B_a.

Reinforced concrete buildings [4.2]

- *Structural system [4.2.1]:* prevalent type of vertical structures (multiple-choice table is given in the manual).
- *Infill walls [4.2.2]*: percentage of the perimeter walls of the building that are closed by infill panels.
- *Year of construction [4.2.3]*: year of construction of the building, as deduced from the building licence or land registry records.

3.3 Damage assessment [4.3]

Within this section, the possible damage of the structural elements shall be reported, such as, for instance, cracks and deformations that could compromise the structural safety of the unit.

4 Appraisal of the vulnerability for masonry buildings

The following paragraphs describe the procedure adopted for evaluating the vulnerability index in the case of masonry buildings. Instead of the 11 vulnerability parameters provided by the original vulnerability index method (Benedetti and Petrini 1984; GNDT 1994), the number was reduced to 10 (*Parameter 8–Distance between bearing walls* was eliminated). The reason for this reduction is to allow the filling of the forms based on an external survey only. This is a crucial point, since in many case it is not possible to visit the building interior, and the vulnerability assessment would be invalidated. In particular, Parameter 8 of the original GNDT form involves the maximum distance between load-bearing walls, and it cannot be easily evaluated without accessing the building or without a plan of the ground floor.

Moreover, many of the vulnerability parameters have been significantly simplified. The numbering of the parameters, anyway, is left unvaried, in order to facilitate the comparison between the two methods. Hereinafter, the notation URM will be adopted to indicate Unreinforced Masonry and RM for Reinforced Masonry.

4.1 Vulnerability Parameters

Parameter 1 – Type and organisation of the resisting system - It takes into account the capacity of the building to withstand horizontal loads. This parameter is related to the in-plan organisation of the resisting masonry walls (which should be well distributed along the two main orthogonal directions, and effectively connected each other) and to the presence of rigid floors efficiently connected to the walls.

The first element considered for the assignment of the class is the box-like behaviour of the structure, appraised by considering the following elements: presence and effectiveness of the connections between walls, presence of ring beams or ties. The assignment of the lowest vulnerability class takes also into account the evolution of national seismic codes. It is supposed that the adoption of a more severe seismic classification determines a greater attention to detail and quality of the construction. Finally, the vulnerability class is assigned according to Table 1. After assigning the vulnerability class, the score can be modified to take into account the presence of later alterations of the building (enlargements, additional storeys), seismic retrofitting or improvement interventions. The modifiers adopted in the algorithm are listed in the manual (ANTAEUS Project, 2011).

Parameter 2 – Quality of the resisting system - This parameter describes the quality of the masonry: materials (blocks and mortar), organisation (homogeneity, interlocking...). It is mainly based on a qualitative description, as provided in the Section [4.1.1] of the survey form. In the case of masonry walls with rubble infill, the presence or absence of effective headers is considered as an additional parameter. The assignment of the class is done according to Table 2.

Parameter 3 – **Conventional capacity** - In the 2^{nd} level GNDT form for masonry buildings, the 3^{rd} parameter used is the conventional resistance, which requires measuring the in-plan area

 In the case of ANTAEUS form, it was not possible to provide a so detailed level of investigation by the surveyors, who were asked to work quickly. In addition, information available from land registry plans was lacking: for over 50% of the buildings, no plan at all was retrieved. Thence, the evaluation of this parameter was deeply revised, introducing a simpler, alternative index conceived in order to roughly represent the seismic capacity of the building. The fundamental approximation is that each structural unit can be considered a *simple masonry building* according to the definition of current seismic codes (NTC 2008; CEN 2005). For this kind of buildings, no explicit seismic verification is required, and it is admitted that the safety assessment can be performed under the vertical loads alone, with a proper safety factor. According to this approach, we have chosen to express the conventional seismic capacity by means of the following index of resistance to vertical loads (I_{RV}) :

$$I_{RV} = \frac{\sigma_M}{f_M / \gamma_M} \tag{1}$$

where:

• γ_M is the partial safety factor for masonry ($\gamma_M = 4.2$, as specified by the Italian Building Code –Chapter 4, Par. 4.5.6.4 for simple masonry buildings);

- f_M is the average compressive strength of masonry;
- $\sigma_M = \frac{N}{A}$ is the normal stress at the ground floor;

• $N = W_T$ is the total vertical load at the ground floor, estimated by considering dead and live loads of all storeys ($\gamma_G = \gamma_Q = 1$) plus the weight of the load-bearing walls (with no deduction for the openings). The calculation is performed with an approximated automatic procedure, taking into account the geometry of the building and the typology of vertical structures (the complete procedure is explained in detail in the manual – ANTAEUS Project, 2011).

The assignment of the vulnerability class is made according to Table 3, on the basis of I_{RV} .

Parameter 4 – **Topographic conditions** - In the original GNDT procedure, detailed information is required about the topographic condition and foundations of the building. ANTAEUS form only includes qualitative information about the topography (*Morphology of the site* - sec. [3.1.3]), which is visually appraised, whereas specific data about the foundation system - which are nearly impossible to obtain at this level - are disregarded. The assignment of the vulnerability class is made according to Table 4.

Parameter 5 – **Floors** - In agreement with the 2^{nd} level GNDT form, the assignment of the vulnerability class is based on in-plane stiffness of floors, and on the effectiveness of the connections to the walls. Weighting coefficients are introduced in order to account for the percentage of rigid and well-connected floors with respect to the total amount.

The entries involved are those reported in Section [4.1.2] of the survey form, and the assignment of the vulnerability class is made according to Table 5.

Parameter 6 – Configuration in-plan – This vulnerability parameter is evaluated in the Section [3.1.2] of the form. Two different indicators are considered. The first one is the regularity in-plan: it is the same used by the GNDT method, and the surveyor directly assigns the vulnerability class in the form.

In addition to the GNDT method, the position of the unit within the aggregate is considered as a specific vulnerability factor, as suggested by many recent research studies (D'Ayala and Paganoni 2011; Giovinazzi et al 2004). To this aim, a proper modifier is applied to the vulnerability score (as described in the manual).

Parameter 7 – **Configuration in elevation** - This parameter takes into account the seismic vulnerability induced by irregularities in elevation (presence of recessed additional storeys, towers...). It is directly calculated by the surveyors - in Section [3.1.2] - with the same method

 of the GNDT form.

Parameter 9 – Roof – The vulnerability class associated with this parameter is obtained from Section [4.1.3], assuming that thrusting roofs involve a higher vulnerability level. The presence of ties that can partially eliminate the thrust is also taken into account (Table 6).

Parameter 10 – Non-structural elements – It takes into account the vulnerability and damages induced by non-structural elements (balconies, cornices, eaves, chimneypots...) that are not properly connected to the structure (Section [3.1.6]). Table 7 provides the vulnerability class as a function of the number of vulnerable elements.

Parameter 11 – **Maintenance level** - This parameter takes into account the general maintenance of the building, structures and fixtures. The assignment of the basic vulnerability class is determined by the presence (and extent) of damage to roofs and vertical structures (Table 8). The presence of damage in non-structural elements, together with the general state of preservation of the building, is taken into account by means of score modifiers (which are are reported in the manual).

4.2 Calculation of the vulnerability index - I.V.

For each of the 10 parameters previously described, a vulnerability class (from A to D) is assigned and, according to Table 9, this is translated into a numerical score p_i , which can vary in the range [0,45]. Then, the possible modifiers are applied (the final modified value of p_i cannot exceed the limits of the aforementioned interval).

The vulnerability index I.V. is obtained by a weighted sum of the obtained scores: $p_1w_1 + p_2w_2 + \dots + p_{10}w_{10}$ and can vary within the interval [0, 292.5]. w_i are weighting coefficients (Table 9) introduced in order to calibrate the different influence of each parameter on the overall vulnerability of the structural unit.

Finally, the vulnerability index I.V. is normalized between 0 and 1 according to the

following expression:

$$I.V. = \frac{(p_1w_1 + p_2w_2 + \dots + p_{11}w_{11})}{292.5} \tag{2}$$

Both for scores p_i and weights w_i , the values originally attributed by GNDT were changed in order to balance the different quality of information of the ANTAEUS form. In particular, the importance of parameters 1 and 3 was decreased, since their definition is less accurate. For parameters 5, 7 and 9, instead, weights were not varied.

5 Appraisal of the vulnerability for RC buildings

The application of the vulnerability index method for RC buildings is much less established than for masonry buildings. In this regard, the ANTAEUS project started from the existing references and experiences (GNDT 1999; Regione Molise 2002; Regione Marche 2004; Regione Toscana 2013) for re-elaborating some elements of the methodology: choice of sensitive data, number and type of vulnerability parameters, assignment of the vulnerability classes, scores, weighting coefficients, and combining algorithm. The calculation of the vulnerability index is similar to the one for masonry buildings except for the different range of variation, which is [-27.5, 247.5]. This difference is related to the general lower vulnerability level of this structural system. Moreover, the number of vulnerability parameters is further reduced to 8.

5.1 Vulnerability parameters

Parameter 1 – Type and organisation of the resisting system – The evaluation of the vulnerability of the resisting system is based on the structural typology and the year of construction (Table 10). Besides, it is supposed that the evolution of seismic classification and national seismic codes over the years has involved a higher quality. If seismic retrofitting

International Journal of Architectural Heritage

interventions have been implemented, the class is assigned by substituting, in Table 10, the year of construction with the year of the intervention. Finally, vulnerability score is modified in order to take into account the percentage T% of infill panels with respect to the area of the façade (entry [4.2.2] of ANTAEUS form – see Appendix), according to the criteria shown in the manual (ANTAEUS Project 2011).

Parameter 2 – Quality of the resisting system - This parameter accounts for the quality of the resisting system with respect to materials and execution. It is related to the construction year, since it is supposed that the evolution of seismic codes involves more stringent requirements about the quality and the performance of materials (e.g., introduction of the use of ribbed rebars in place of smooth ones). The vulnerability score is assigned according to Table 11.

Parameter 3 – **Index of seismic rating I**_{SR} - This parameter expresses the conventional resistance of the building. Under the hypothesis that each examined building was designed by respecting in-force building codes, we accept that the actual seismic capacity coincides with the design seismic capacity, as required by the code. The index is calculated as the ratio between the maximum design base shear V_{des} (provided by the building code in force at the year of construction Y_c) and the current one V_{cur} (i.e. calculated according to the present Italian seismic code, with reference to the maximum seismic demand in the region):

$$I_{SR} = \frac{V_{des}}{V_{cur}} \cdot 100$$

(3)

The base shears (both design and current one) are calculated by adopting the method of *linear static analysis* (the automatic calculation procedure is explained in detail in the manual, ANTAEUS Project, 2011). The final assignment of the vulnerability is given in Table 12.

Parameter 4-6-7-10-11- For all these parameters, the criteria used to assign the vulnerability

class are the same to the case of masonry buildings.

5.2 Calculation of the vulnerability index

For each of the 8 parameters, a vulnerability class (from A to D) is assigned, and this is translated into a numerical score p_i , according to Table 13. Then, the possible modifiers affecting the parameter are applied. In any case, the final modified value of p_i cannot exceed the following limits:

- $0 \div 45$ for parameters 4-6-7-10-11;
- $-10 \div 45$ for parameters 1 and 2;
- $-5 \div 45$ for parameter 3.

If these thresholds are exceeded after the application of modifiers, the score p_i is set back to the maximum or minimum value.

The vulnerability index I.V. is obtained by a weighted sum of the scores obtained for each parameter: $p_1w_1 + p_2w_2 + \dots + p_{11}w_{11}$. It can vary within the interval [-27.5, 247.5] (the weighting coefficients w_i are listed in Table 13).

Finally, the vulnerability index I.V. is normalized between -0.25 and 1, according to the following expression:

$$I.V. = \frac{\{p_1w_1 + p_2w_2 + p_3w_3 + \dots + p_{11}w_{11} + 27.5\}}{220} - 0.25$$
(4)

6 The case study: four historical centres in the Province of Foggia

The ANTAEUS project involved four historical centres in the Province of Foggia (Puglia, Italy): *Foggia, Carlantino, Sant'Agata di Puglia* and *Vico del Gargano* (Fig. 2), where the survey form described in the previous paragraphs was filled for 4519 residential buildings (90% 16

are masonry buildings).

6.1 Foggia

Foggia is a city of 150 000 inhabitants, administrative centre of the homonymous province, located at the centre of a vast alluvial plain, and it is built on flat terrain made up of clay. Born as an agricultural centre, the city took some importance in the 13th century, under the reign of Frederick II Hohenstaufen, who established there an imperial seat. Over the centuries, the city became important as the centre of the surrounding agricultural region and underwent considerable expansion. A remarkable seismic event was the earthquake of 1731 (Mezzina 2011), that severely damaged the city and destroyed about one third of the building stock. The current layout of the historical centre is deeply influenced by the reconstruction process that followed: besides the great number of collapsed buildings, unsafe structures were demolished and replaced by one-storey masonry shacks, built with tuff stone and coupled to each other to form large blocks. Over the centuries, people have modified these temporary buildings with expansions, fusions and addition of storeys (Fig. 4), making them a permanent part of the city, as it is clearly visible in the urban fabric (Fig. 3). In the other parts of the old city, the common typology is represented by two-storeys tuff masonry buildings, built before 1919.

6.2 Vico del Gargano

Vico del Gargano is located in the Northern part of the Gargano Promontory, on a hill made up of limestone of dolomitic type. The historical centre grew around the core of the old castle, which is still visible (Fig. 5). Over the years, residential buildings have replaced the ancient city walls, whose path still defines the perimeter of the old town. The geometry of the buildings, mostly built of stone, is strongly unhomogeneous in plan and elevation, also because of alterations made at different times. Masonry is generally very regular, consisting of roughly cut stones, in some cases in weak condition because of the state of abandonment. The town of *Sant'Agata di Puglia* is located at the foot of Apennine Mountains. The town is built on the eastern side of a hill around the ancient castle, which is on the top. The soil consists of a conglomerate with particles of ruditic size. The buildings – usually, two-storey masonry constructions – are built on a steep slope, and characterized by irregularity in elevation (different number of storeys towards the valley and towards the mountain, as shown in Fig. 6). Moreover, many buildings have an underground artificial cave, with the entrance at the lower level. The walls are mostly made up of roughly squared limestone blocks. The maintenance status of the walls is generally good.

6.4 Carlantino

The town of *Carlantino* is also located on the Apennine Mountains, at the extreme border of the Province of Foggia. The town has developed since the 16th century as a farming settlement and has no fortification work that influenced its development. The urban fabric looks sparser than other towns (greater distance between houses and wider streets). On average, buildings are two-storeys, and in many cases have been recently renovated or enlarged. The soil mainly consists of agglomerate of rocks of variable grain and size.

7 Validation of the methodology for masonry buildings: comparison with GNDT method

After completing the survey in the four municipalities, ANTAEUS procedure was statistically validated by comparing it with other established vulnerability methods (GNDT 1994; Ferrini et al 2003). For each municipality, a representative sub-sample of masonry buildings was selected, choosing those for which forms were complete and reliable (Table 12). We restricted our attention on masonry building only, because the overall number of RC buildings involved in

International Journal of Architectural Heritage

the surveys was small with respect to the total set (less than 10%): the statistical significance of the sample would have been limited, compromising the relevance of the validation.

The comparison concerned the GNDT approach for the 2^{nd} level vulnerability assessment of masonry buildings in its original version (GNDT 1994) and in the modified version adopted by Tuscany Region (Ferrini et al 2003) and extensively applied in 2003. The survey form used in the two approaches is equivalent, whereas the main differences concern the values of the weighting coefficients attributed to the parameters, as shown in Table 13. When the value of the weighting coefficient is not unique but varies within an interval, the table reports the varying range and – in round brackets - the mean value obtained on the sample. For each building of the sample, the GNDT/Tuscany form was filled by deducing the data from the ANTAEUS form and accordingly calculating the vulnerability index. In order to fill the GNDT forms it was necessary a further process¹ and – in some cases – an integration by additional surveys.

7.1 Analysis of the results and calibration of the algorithm

In this paragraph, the comparison among the results provided by each of the three methods (GNDT, GNDT–Tuscany, ANTAEUS) is presented and discussed.

7.1.1 Analysis of the sample of Foggia

In the first instance, the analysis was performed on the sample of buildings of the City of Foggia that is the largest one (75 buildings). Figure 7 reports the average score provided by the three methods for each of the 11 vulnerability parameters in absolute terms, i.e. without normalizing scores and without applying weighting coefficients (the values provided by GNDT

¹ In many cases, form data were not sufficient, but the attached material (pictures, plan and sectional views...) was sufficient for deducing the necessary information.

and GNDT-Tuscany, in absolute terms, are coincident). The major deviations are encountered for Parameter 2 (Quality of resisting system), Parameter 3 (Conventional resistance), and Parameter 10 (Non-structural elements), which are those for which the ANTAEUS methodology has introduced significant simplifications or variations. After the application of the weights and normalization, however, the situation changes, and the incidence of these discrepancies is much reduced (thanks to the fact that the ANTAEUS algorithm attributes a lower weight to these parameters). By analysing in detail the individual weighted parameters, the performance of the three methods is different: variations can be noticed among all approaches, for almost all parameters. At this stage, it is difficult to perform a direct comparison, whereas it is more useful to look at the final objective, that consist in guaranteeing that the vulnerability index is substantially consistent among the different approaches. In this sense, the discrepancy between the overall vulnerability index in the ANTAEUS method and in GNDT/GNDT-Tuscany is quite limited, and could be compatible with the purposes of a large regional scale assessment. It is anyway possible to further reduce it, and, to this aim, it is convenient to operate on Parameter 1, which contributes for about 40% to the final value (19.9 points on a total of 48.9). After some simulations aimed at the optimization of the result, it was decided to reduce the weight of the parameter from 1.50 to 0.75.

In Figure 8–left, the distribution of the vulnerability index is plotted for GNDT, GNDT– Tuscany, ANTAEUS (1st proposal), modified ANTAEUS (after calibration). These diagrams summarize all the observations previously presented, showing, in particular, that the distribution relative to the final calibration of the ANTAEUS method is well consistent with the other methods.

7.1.2 Analysis of the samples of Carlantino, Sant'Agata, Vico del Gargano

The same comparative analysis was performed for the other three municipalities. By applying the calibration proposed for the sample of Foggia (i.e., simply modifying the weight of

 Parameter 1 from 1.50 to 0.75), the difference between the results of the algorithms is minimised. In particular, Figure 8–right shows the average values and the distribution of the vulnerability index for GNDT, GNDT–Tuscany, ANTAEUS (1st proposal), modified ANTAEUS (after calibration).

8 Analysis of the quality of data

The filling of the survey forms is performed by means of an editable PDF module that can be directly interfaced with the database. At the end of field operations, all filled PDF forms are processed by a specific software² in order to extract the sensitive data contained in the different fields of the form, and create the database to be used for further elaborations.

8.1 Management of incomplete information: reliability of the forms

A first screening of the vulnerability forms and the extracted database revealed the presence of a large amount of incomplete forms (30% of the total), in which missing data were so many as to invalidate the form itself. This number seemed to go beyond the expected physiologic percentage, especially considering that ANTAEUS form was specifically designed for extending the procedure to the largest possible number of buildings. Invalid forms were analysed in detail, in order to discern occasional errors (related to the specific surveyor teams) from reasons intrinsic to the structure of the form or compelling boundary conditions. It was ascertained that,

² Data management and processing has been carried out by means of *open source* software, which ensures maximum compatibility and portability of the code. *Pdftk* (http://www.pdflabs.com/tools/pdftk-the-pdf-toolkit/) was used for data extraction from PDF files and creation of CSV files. *OpenOffice* (http://www.openoffice.org/) was used for IV calculation and statistical analysis, and *Quantum GIS* (http://www.qgis.org/) was used for the plotting of the maps.

for most of the invalid forms, the problem was the inability to access the interior of the buildings, and thence the lack of information about the structure and related vulnerability data, which are fundamental for the application of the ANTAEUS algorithm. In the absence of these vulnerability parameters, it is not possible to calculate the vulnerability index and the whole form is unusable. Such a problem can be very common for buildings located in Italian historical centres, because many houses are uninhabited or used only during holidays.

At this point, a question about the management of incomplete information rises, in order to reduce the effects of invalid forms, and we introduced some adjustments in the algorithm by providing an automatic a posteriori estimate for missing fields, allowing to proceed in the calculation of the vulnerability index, although approximately. In other words, a limited loss of reliability was accepted in favour of the increase of the valid samples. Within the framework of a regional scale analysis, the interpolation of missing data does not significantly affect the general meaning of results.

After this post-processing, it is necessary to control the reliability level of the results and keep a trace of defective information, by properly differentiating the quality of forms containing revised or integrated data. To this aim, a reliability index I_R was assigned to each form, by taking into account the number of extrapolated parameters: the lower the index, the lower the reliability of the form. Every time that a missing parameter is forced to an extrapolated value, 1 point is subtracted from the reliability index (a value $I_R = 0$ indicates maximum reliability). The minimum accepted value of the reliability index is -3. All forms were classified according to their reliability index, as shown for example in Figure 9 (which is relative to the city of Foggia, after the 2nd survey). In the map, it should be noted that fractional values of the reliability index appear. This is due to the evaluation of the parameter "*Area of vertical structures*", which expresses the percentage of masonry piers in-plan, with respect to the total covered area. (Section [4.1.1] of the form – see Appendix), which was misinterpreted by some of the survey

URL: http://mc.manuscriptcentral.com/uarc Email: pbl@civil.uminho.pt; pere.roca.fabregat@upc.edu

teams and required a specific evaluation³.

8.2 Management of operator-dependant errors

With regard to the qualitative analysis of data, an important aspect concerns the verification of the efficiency of survey teams with the consequent detection of systematic errors in the surveyed data (subjectivity of reading/interpretation of data; inhomogeneity in the level of training and experience of the operators...). In this regard, a check procedure was provided, by properly processing and analysing the database as a function of the reliability index of buildings' forms. In particular, statistical analyses were made in order to classify forms according to the reliability index, assess the average reliability index for each municipality and, more in detail, for individual teams (Table 14, Table 15). The GIS provides an effective and immediate representation that was particularly useful during the operational phase of survey for immediately identifying problems. For example, Table 15 shows that the quality of data collected by the different teams in the city of Foggia is quite heterogeneous. There was no particular evidence of a geographic correlation, that is to say, a same team has a reliability level that is substantially constant over all the different areas of competence (i.e., the reliability cannot

- ³ Occasionally the values reported were grossly incorrect, since probably some teams had reported the absolute value of the vertical structures, expressed in square meters. The parameter was checked and recalculated as follows:
 - Values comprised in the range [0.15, 0.30] were considered valid (% of covered area).
- In a first instance, values >1 were interpreted as the area $[m^2]$ of the vertical structures. The % value was numerically calculated. If this was comprised in the interval [0.15, 0.30], it was accepted, but the reliability index was penalized by 0.5 points.

- In all other cases, the value was considered invalid, and the area of the vertical structures was conventionally set to 20% of the covered area in-plan (which was the average value of the parameter on valid forms). The reliability index was penalized by 1 point.

be ascribed to an objective difficulty in retrieving data at certain locations). Based on this analysis, the coordinators of the teams were promptly alerted for a rapid intervention and possible sanitization of the problem.

In *Vico del Gargano*, instead, the map of the vertical structures showed a cluster of buildings with a masonry typology different from the surroundings, whereas it was expected to find uniform masonry fabric. The comparison with the spatial distribution of survey teams revealed that the whole cluster had been assigned to a single team, who made a systematic error in the interpretation of this factor (Figure 11). In this case, coordinators were alerted and the error was promptly corrected.

9 Application of the algorithm and discussion of the results

Municipality of Foggia

The average value of the I.V. calculated for masonry buildings (about 93% of total) with the modified ANTAEUS algorithm is equal to 0.45. It can be noticed that the average values obtained over the entire population are very similar to the values obtained on the basis of the sub-sample selected for the calibration (Table 14), which confirms the validity of the calibration procedure. Figure 12 shows the map of the index of vulnerability calculated with the modified version of the ANTAEUS algorithm.

Municipalities of Vico del Gargano, Sant'Agata di Puglia and Carlantino

The average value of the I.V. calculated on the entire population of buildings with the modified ANTAEUS algorithm is equal to 0.51 for Vico del Gargano, 0.56 for Sant'Agata di Puglia and 0.46 for Carlantino (Table 15). These data are consistent with the prediction provided by the preliminary analysis carried out on the samples.

10 Final Remarks

The main objective of the research study was to develop and validate a procedure that can be applied at a large, regional scale by local authorities, in order to obtain a pre-event vulnerability assessment and establish a rational basis for the risk mitigation strategies and territorial development policies. In this sense, this regional project represents, in Puglia, a pilot experience that could be extended to other areas of Southern Italy presenting a building stock with similar characteristics.

The proposed survey procedure is quite simple, excluding data that were too unreliable and difficult to retrieve, in order to rationalise the fieldwork and limit as much as possible uncertainty and errors. A specific survey form is provided, which is an editable PDF module directly connected with a database, together with an algorithm for the appraisal of the index of vulnerability. The procedure is derived by the classical GNDT method, even if some significant modifications of the survey form and the vulnerability algorithm were introduced, with the idea of obtaining a simplification and a better accounting for the regional features.

Actually, since Puglia is a low-medium hazard region, few observational data about postearthquake events are available, which makes impossible to perform a statistical validation. The validation of the ANTAEUS procedure, thence, was made with an indirect approach, by performing a detailed comparison, on a sample of buildings, with the results provided by GNDT and GNDT-Tuscany methods. The results were critically evaluated, introducing the necessary calibrations, which actually consisted in the adjustment of the weighting coefficient for one parameter (see Section 7.1). Overall, the three compared methods exhibit discrepancies with regard to individual parameters, but the correspondence in terms of the final vulnerability index is good.

The results can be considered satisfactory within the scope and objectives of the project: the

assessment procedure was performed by using a very simplified data-sheet and in a short time by providing an estimate of the vulnerability level compatible with more detailed approaches. An important issue considered in the study was the analysis of the quality of the data with respect to the issue of the uncertainty factors related to the phase of data retrieval (quickness and roughness of rapid visual inspections, possible incompleteness of collectable information, subjectivity of data reading/interpretation...). A detailed reliability analysis of the results was performed, in order to identify critical points and propose a sanitization of the database. The management of incomplete/erroneous data was made by activating a fruitful interaction between the scientific board and the coordinators of the survey teams, and allowing a prompt intervention both on theoretical aspects (by means of proper a-posteriori re-elaboration of data) and operational issues (by performing *ad hoc* controls and integrations on site).

Aknowledgements This research project was developed with the financial support and coordination of *AdB Puglia - Autorità di Bacino della Regione Puglia (Basin Authority of Puglia)*, within the program "Studio di Fattibilità per il Monitoraggio e la Messa in Sicurezza delle Aree Urbane a Rischio di Stabilità Statica e Vulnerabilità Strutturale nella Città e Provincia di Foggia" (CIPE 20/2004). In particular, the results presented in this paper were achieved thanks to specific financial and scientific agreements stipulated between the local governments (Province of Foggia and City of Foggia) and Politecnico di Milano, and between AdB Puglia and Politecnico di Bari.

11 References

ANTAEUS Project, 2011- Research Program "Studio di Fattibilità per il Monitoraggio e la Messa in Sicurezza delle Aree Urbane a Rischio di Stabilità Statica e Vulnerabilità Strutturale nella Città e Provincia di Foggia", Politecnico di Bari, Politecnico di

Milano, Province of Foggia and City of Foggia.

http://www.stru.polimi.it/people/sanjust/bacheca/Manuscripts/ANTAEUS manual.pdf

- Benedetti D., Petrini V. 1984. Sulla vulnerabilità sismica di edifici in muratura: un metodo di valutazione (*On the seismic vulnerability of masonry buildings: a method of evaluation*). *L'industria delle costruzioni* 18(149):66–74. (In Italian)
- Calvi G., Pinho R., Magenes G., Bommer J., Restrepo-Velez L., Crowley H. 2006. Development of seismic vulnerability assessment methodologies over the past 30 years. ISET Journal of Earthquake Technology 43(3):75–104, http://home.iitk.ac.in/vinaykg/Iset472.pdf>
- Casolo S., Milani G., Uva G., Alessandri C., 2013. Comparative seismic vulnerability analysis on ten masonry towers in the coastal Po Valley in Italy. Eng. Struct. 49:465–490.
- Casolo S., Neumair S., Parisi M.A., Petrini V. (2000) Analysis of seismic damage patterns in old masonry church facades. Earthq. Spectra 16(4):757–773, http://dx.doi.org/10.1193/1.1586138
- Casolo S., Sanjust C.A., 2009. Seismic analysis and strengthening design of a masonry monument by a rigid body spring model: The "Maniace Castle" of Syracuse. Eng. Struct. 31(7):1447–1459
- Casolo S., Uva G., 2011. Seismic vulnerability assessment of masonry towers: Full non-linear dynamics vs pushover analyses. *Proceedings of COMPDYN 2011: 3rd International Conference on Computational Methods in Structural Dynamics and Earthquake Engineering: An IACM Special Interest Conference*, Corfu, Greece, 2011.

Castorani A., Di Santo R., Fratino U., Limongelli R., Mezzina M., Pagano A., Raffaele D., Trulli
I. 2011. Methodological Approach to Evaluate Multihazard Risk on Bridges and
Viaducts. *Italian Journal of Engineering Geology and Environment*, Special Issue 1, pp.
19-32. DOI: 10.4408/IJEGE.2011-01.S-02

CEN, 2005. EuroCode8: Design of structures for earthquake resistance - Part 1: General rules, 27

seismic actions and rules for buildings. European Standard approved by CEN on 23 April 2004.

- Civil Protection Department of the Presidency of Council of Ministers. Website http://www.protezionecivile.gov.it/jcms/it/terremoto molise 2002.wp
- Corsanego A., 1993. Sismic risk assessment at the urban and regional scale in Italy: some examples. Ann. di Geofis. 36(1):211–218.
- Cosenza E., Manfredi G., Polese M., Verderame G.M. 2005. A multi-level approach to the capacity assessment of existing RC buildings. J. Earthquake Eng. 9(1):1–22
- D'Ayala D., Benzoni G. 2012. Historic and traditional structures during the 2010 Chile earthquake: Observations, codes, and conservation strategies. *Earthq. Spectra* 28 (1): S425–S451.
- D'Ayala D., Paganoni S. 2011. Assessment and analysis of damage in L'Aquila historic city centre after 6th April 2009. B. Earthq. Eng. 9(1):81–104, DOI 10.1007/s10518-010-9224-4
- Dolce M., Masi A., Marino M., Vona M. 2003. Earthquake Damage Scenarios of the Building Stock of Potenza (Southern Italy) Including Site Effects. B. Earthq. Eng. 1(1):115.
- FEMA. 2012. Multi-hazard Loss Estimation Methodology Technical Manuals and User's Manuals for: the Earthquake Advanced Engineering Building Module (AEBM), the Earthquake Model, the Flood Model, and the Hurricane Model. Federal Emergency Management Agency (FEMA), National Institute of Building Sciences, Washington DC, USA
- Ferrini M., Melozzi A., Pagliazzi A., Scarparolo S. 2003. Manuale di rilevamento della vulnerabilità sismica degli edifici in muratura, per la compilazione della Scheda GNDT/CNR di II livello versione modificata dalla Regione Toscana. Regione Toscana Direzione Generale delle Politiche Territoriale e Ambientali. (In Italian).

Giovinazzi S, Balbi A, Lagomarsino S, 2004. Un modello di vulnerabilità per gli edifici nei
centri storici (A vulnerability model for buildings in historical centres). In: Proceedings
XI Convegno ANIDIS - L'Ingegneria Sismica in Italia, Genoa, Italy, 2004, (In Italian)

GLABEC. 2001. Post-Eartquake emergency – Survey form for monumental buildings –

Churches. Work Group for the protection of the Cultural Heritage from natural risks DM n. 133 23/01/2001, Rome, Italy, http://www.beniculturali.it/-

mibac/multimedia/MiBAC/documents/1338454237471_allegato4.pdf>

- GNDT. 1994. Scheda di esposizione e vulnerabilità e di rilevamento danni di primo livello e secondo livello (muratura e cemento armato) (Exposition, vulnerability and damage 1st and 2nd level survey form). GNDT (Italian Group for the defense against earthquakes), (In Italian)
- GNDT. 1999. Vulnerability Inventory of strategic and special buildings in Abruzzo, Basilicata, Calabria, Campania, Molise, Puglia and Eastern Sicilia. Tech. rep., GNDT - (Italian Group for the Defense Against Earthquakes), Italian Ministry of Labour, Civil Protection, Rome, Italy, URL ftp://ftp.ingv.it/pro/gndt/Pubblicazioni/Censimenti.htm. (In Italian)
- GNDT, 2000. Vulnerability survey of part of residential buildings in Abruzzo, Basilicata,
 Calabria, Campania, Molise and Sicily Regions. Tech. rep., GNDT (Italian Group for
 the defense against earthquakes), Italian Ministry of Labour, Civil Protection, Rome,
 Italy, (In Italian)
- GNDT. 2001. Survey of monumental buildings located in national or regional natural parks.Tech. rep., GNDT (Italian Group for the defense against earthquakes), Italian Ministry of Labour, Civil Protection, Rome, Italy. (In Italian)
- Goretti A., Di Pasquale G. 2002. An overview of post-earthquake damage assessment in Italy. In: *Eeri Invitational Workshop An Action Plan To Develop Earthquake Damage And Loss Data Protocols*, Pasadena, California, USA

- Lagomarsino S. 2012. Damage assessment of churches after L'Aquila earthquake (2009). B. Earthq. Eng. 10:73–92, doi:10.1007/s10518-011- 9307-x
- Lagomarsino S., Giovinazzi S. 2006. Macroseismic and mechanical models for the vulnerability and damage assessment of current buildings. B. Earthq. Eng. 4(4):415, doi:10.1007/s10518-006-9024-z
- Lagomarsino S., Podesta S. 2004a. Seismic vulnerability of ancient churches: I. damage assessment and emergency planning. Earthq. Spectra 20(2):377–394
- Lagomarsino S., Podestà S. 2004b. Seismic vulnerability of ancient churches: II. Statistical analysis of surveyed data and methods for risk analysis. Earthq. Spectra 20(2):395–412
- Mansour A.K., Romdhane N.B., Boukadi N. 2013. An inventory of buildings in the city of Tunis and an assessment of their vulnerability. B. Earthq. Eng. 11:1563-1583
- Mezzina M. 2011. Ricostruire dopo il terremoto: due esperienze illuministe alla periferia del Regno Borbonico (in Italian). *Proc. XIV Convegno Anidis*, Bari (Italy), 18-20 September 2011.
- Mezzina M., Palmisano F., Raffaele D. 2012. A simplified procedure to evaluate seismic vulnerability of R.C. circular bridge piers. *Proceedings of the Sixth International Conference on Bridge Maintenance, Safety and Management*, Taylor & Francis Balkema, Stresa, Italy, pp 3525–3532
- Milani G., Casolo S., Naliato A., Tralli A. 2011. Seismic Assessment of a Medieval Masonry Tower in Northern Italy by Limit, Nonlinear Static, and Full Dynamic Analyses. Int. J. of Archit. Herit. 6(5):489–524, doi:10.1080/15583058.2011.588987
- NTC. 2008. Norme Tecniche per le Costruzioni (*Italian Building Code*) NTC. Gazzetta Ufficiale n. 29 - Suppl. Ordinario n. 30
- Petrini V., Casolo S., Doglioni F. 1999. Models for vulnerability analysis of monuments and strengthening criteria. In: *Proceedings of the XI European Conference on Earthquake Engineering*, Baalkema, Paris, vol of Invited Lectures, pp 179–198.

Raffaele D., Mezzina M., Tosto A.F. 2013a. Overview on the regional scale analysis of school
buildings in Puglia (Italy). In: Proceedings of COMPDYN 2013 – 4 th ECCOMAS
Thematic Conference on Computational Methods in Structural Dynamics and
Earthquake Engineering, Kos Island, Greece, 12-14 June 2013.
Raffaele D., Porco F., Fiore A., Uva G. 2013b. Simplified vulnerability assessment of reinforced
concrete circular piers in multi-span simply supported bridges. Struct. Infrastruct. E. pp
1-13, doi:10.1080/15732479.2013.772642
Regione Marche. 2004. Rischio Sismico nelle Regione Marche (Seimic Risk in Marche Region).
(In Italian) http://rischiosismico.regione.marche.it/web/RISCHIO-
<u>SI/Vulnerabil/index.htm</u> .
Regione Molise. 2002. Servizio Informativo Sisma 2002 (Molise Region: information on 2002
seismic event), 2002. (In Italian). Last accessed: 14 Nov. 2013.
<http: grm="" sis.nsf="" web="" www.regione.molise.it="">.</http:>
Regione Toscana. 2013. Il rischio sismico nelle Regione Toscana (Seismic risk in Tuscany),
2013. Last accessed: 14 Nov. 2013. (In Italian)
<http: index.shtml="" pta="" sett="" sismica="" www.rete.toscana.it="">.</http:>
RISK-UE. 2004. An advanced approach to earthquake risk scenarios with applications to
different European towns (RISK-UE).
http://cordis.europa.eu/search/index.cfm?fuseaction=proj.document&PJ_RCN=4939039
Rota M., Penna A., Strobbia C. 2008. Processing Italian damage data to derive typological
fragility curves. Soil Dyn. Earthq. Eng. 28(10-11):933-947,
doi:10.1016/j.soildyn.2007.10.010
Rota M., Penna A., Strobbia C., Magenes G. 2011. Typological seismic risk maps for Italy.
Earthq. Spectra 27(3):907-926, doi:10.1193/1.3609850
Zuccaro G. 1996. Metodi di Analisi di Vulnerabilità e Matrici di Probabilità del Danno 31

(Vulnerability analysis methods and damage probability matrices). In: Proceedings Of

Appendix

The ANTAEUS Vulnerability form is an editable PDF file, which is intended to be filled in directly on site by the surveyor by means of portable devices (like for instance a tablet). After a <text><text><text><text> final phase of deskwork, when data are checked and additional information is uploaded (land registry plans, pictures, sketches...), the file is closed and sent to the remote system, which automatically extract numerical data and store them in the database. In this appendix, a print of the PDF module is reported, showing the different sections and entries to be filled, which are recalled and described in the different paragraphs of the paper.

ANTAEUS Form for seismic vulnerability	S.U. Number					
Structural unit survey form						
1.1 General of	data					
Team Date Municipality Address n. Census code p. Census code m. Cadastre sheet Cadastre map						
1.2 Photographic	c survey					
Elevation X	Elevation	X				
Elevation X	Elevation	X				

1/4

Politecnico di Bari – vers. 1.04 – 20/07/12
Location (1:500 aggregate plan, aerial view) Ground floor plan	2.1		Graphic survey	/	
Location (1:500 aggregate plan, aerial view) Ground floor plan					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Location (1:500 aggregate plan, aerial view)					
Ground floor plan	Location (1:500 ago	regate plan, aerial vi	ew)		
Ground floor plan					
Ground floor plan					
Ground floor plan					
Ground floor plan					
Ground floor plan					
Ground floor plan					
Ground floor plan					
Ground floor plan					
Ground floor plan					
	Ground floor plan				
	L				

Politecnico di Bari - vers. 1.04 - 20/07/12

2
3
4
5
0
6
7
8
9
10
11
11
12
13
14
15
16
17
10
10
19
20
21
22
23
20
24
25
26
27
28
20
20
30
31
32
33
34
35
36
30
37
38
39
40
41
42
13
40
44
45
46
47
48
10
73
50
51
52
53
54
55
55
30
57
58
59

1

3.1	COMMON DATA				
	Vulnerability indicators	Instructions			
1	Geometric data Lx: Ly:	All measurements in meters [m] or squared meters [m²]. Lx: max. length in x direction Ly: max length in y direction			
2	Morphology of the structural unit Pos. into the aggregate: Irregularities in plan* Irregularities in plan* Irregularities in elevation*	Typology of building: A1 Head A4 Isolated A2 Internal NR Not surveyed A3 Corner			
3	Morphology of the site Morphology of the site	Morphology of the site S1 Flat S4 Hillside S2 On ridge S3 On a slope NR Not surveyed			
4	Maintenance General OB OC Fixtures OB OC A Plaster / cladding OB OC Wiring system OB OC OA Roof OB OC OA Plumbing sys. OB OC OA	Maintenance status B Good C Bad A Lacking			
5	Modifications after construction Raising In masonry In r.c. Extension In masonry In r.c. esismic upgrading year alteration of load-bearing walls esismic retrofitting year alteration of original internal partition local repairs Internal	In the case of upgrading or retrofitting, you should report the year of execution of the works.			
6	Non-structural elements Vulnerable Vulnerable chimney-pot Yes No balcony Yes No cornice Yes No shelters / cantilever roofs Yes No parapet Yes No suspended ceiling Yes No				
7	Prevalent use:	Prevalent use U1 Housing U5 Workshop U2 Commercial U6 Public use U3 Office U4 Industry NR Not surveyed			
* See m	anual				

3/4

Politecnico di Bari - vers. 1.04 - 20/07/12

4.1	MASONRY					
	Vulnerability indicators	Instructions				
1	Vertical structures Typology:	Typology of vertical structures M1.1 Rubble stone M3.1 Unreinforced brick masonry M1.2 Irregular stone masonry M3.2 Reinforced brick masonry M1.3 Regular stone masonry M3.2 Reinforced brick masonry				
2	□ quoins ○ Yes ○ No □ ring beams ○ Yes ○ No Floors Typology:	M2 Tuff blocks NR Not surveyed Typology of floors: 01 Wooden structure 04 Masonry vaults O2 Brick and concrete 03 Brick and steel NR Not surveyed				
3	Roof Typology: O Pitch: O Ities or ring beams Non-pushing	Typology of roof: C1 Wooden structure C4 Masonny vaults C2 Brick and concrete vaults C3 Steel NR Not surveyed				
4	Age of the building Age class:	Age class: 6 From 1972 to 1981 1 Before 1919 6 From 1972 to 1981 2 From 1919 to 1930 7 From 1982 to 1987 3 From 1931 to 1945 8 After 1987 4 From 1964 to 1961 5 From 1962 to 1971				
4.2	REINFORCED CONCRETE					
	Vulnerability indicators	Instructions				
1	Structural system	Typology of structural system RC1 RC frames RC4 Frames and RC RC2 Internal frames and perimeter load-bearing RC5 Frames and RC walls				
2	Infill on façade [%]:	RC3 RC frames with NR Not surveyed strong infill walls				
3	Age of the building Year of construction:	Infill on façade: you should report the percentage of infill compared to the lateral surface of the building.				
4.3	B DAMAGE ASSESSM	ENT				
Verti Floor Stair	cal struct.: O G O L O A Roof: O G O L O A rs: O G O L O A Infili: O G O L O A s: O G O L O A	Damage level: G Serious L Slight A None				
4.4	NOTES	SIGNATURE				

4/4

Politecnico di Bari - vers. 1.04 - 20/07/12

13 List of Figures

Figure 1: Evolution of seismic classification in the Province of Foggia: 1935, 1962, 1981, 2004

Figure 2: Localization of the historical centers object of this study. The Province of Foggia (Puglia), is shaded in gray.

Figure 3: The historical centre of Foggia, with the surveyed buildings in evidence. The area object of the reconstruction of 1731 is marked in red.

Figure 4: On the left, an example of the original configuration of the houses built after the 1731 earthquake. On the right, the same typology of houses after the addition of a storey and an enlargement.

Figure 5: A view of the historical centre of Vico del Gargano (left), and an example of the reuse of the city walls (right).

Figure 6: A view of Sant'Agata historical centre (left), and an example of the typical structural aggregate, built on a slope with two level elevations (right).

Figure 7: Sample of Foggia (top), Carlantino, Sant'Agata, Vico del Gargano (bottom): distribution curves of the vulnerability parameters for GNDT/GNDT–Tuscany (light gray) and ANTAEUS (dark gray).

Figure 8: Distribution curves of the Vulnerability Index for GNDT, GNDT–Tuscany, ANTAEUS and modified ANTAEUS methods. Left: sample of Foggia; sample of Carlantino, Sant'Agata, Vico del Gargano.

Figure 9: Historical centre of Foggia: spatial distribution of the Reliability Index (2nd survey).

Figure 10: Distribution of the reliability index among the surveyed buildings.

Figure 11: Vico del Gargano: comparison between the spatial distribution of masonry types

 and survey teams.

Figure 12: Vulnerability map of Foggia historical centre (modified ANTAEUS algorithm).

Figure 13: Vulnerability map of Vico del Gargano historical centre (modified ANTAEUS algorithm).

Figure 14: Vulnerability map of Sant'Agata di Puglia historical centre (modified ANTAEUS algorithm).

<text> Figure 15: Vulnerability map of Carlantino historical centre (modified ANTAEUS algorithm).

14 List of Tables

Table 1: Masonry Buildings: assignment of the vulnerability class for Parameter 1 (Yc is the year in which the municipality has been seismically classified for the first time).

Table 2: Masonry Buildings: assignment of the vulnerability class for Parameter 2.

Table 3: Masonry Buildings: assignment of the vulnerability class for Parameter 3.

Table 4: Masonry Buildings: assignment of the vulnerability class for Parameter 4.

Table 5: Masonry Buildings: assignment of the vulnerability class for Parameter 5.

Table 6: Masonry Buildings: assignment of the vulnerability class for Parameter 9.

Table 7: Masonry Buildings: assignment of the vulnerability class for Parameter 10.

Table 8: Masonry Buildings: assignment of the vulnerability class for Parameter 11.

Table 9: Masonry Buildings: weights and scores of the vulnerability parameters.

Table 10: RC buildings: assignment of the vulnerability class for Parameter 1 (By = year of construction of the building; Yc = year of seismic classification of the municipality).

Table 11: RC buildings: assignment of the vulnerability class for Parameter 2 (By= year of construction of the building).

Table 12: RC buildings: assignment of the vulnerability class for Parameter 3 (By = year of construction of the building).

Table 13: RC buildings: weights and scores of the vulnerability parameters for RC buildings.

Table 14: Reliability index of the survey forms for the 4 municipalities (4385 total forms).

Table 15: Analysis of the reliability index for the City of Foggia.

Table 16: Total number of buildings surveyed with the ANTAEUS form, number of samples for which the GNDT forms were filled in.

Table 15: Values of the weights used to calculate the vulnerability index for masonry

 buildings.

<text><text><text>



Figure 1: Evolution of seismic classification in the Province of Foggia: 1935, 1962, 1981, 2004





Figure 3: The historical centre of Foggia, with the surveyed buildings in evidence. The area object of the reconstruction of 1731 is marked in red.





Figure 4: On the left, an example of the original configuration of the houses built after the 1731 earthquake. On the right, the same typology of houses after the addition of a storey and an enlargement.



Figure 5: A view of the historical centre of Vico del Gargano (left), and an example of the reuse of the city walls (right).





Figure 6: A view of Sant'Agata historical centre (left), and an example of the typical structural aggregate, built on a slope with two level elevations (right).

L... of it is in the second second





Figure 7: Sample of Foggia (top), Carlantino, Sant'Agata, Vico del Gargano (bottom): distribution curves of the vulnerability parameters for GNDT/GNDT–Tuscany (light gray) and ANTAEUS (dark gray).



Figure 8: Distribution curves of the vulnerability index for GNDT, GNDT–Tuscany, ANTAEUS and modified ANTAEUS methods. Left: sample of Foggia; sample of Carlantino, Sant'Agata, Vico del Gargano.



Figure 9: Historical centre of Foggia: spatial distribution of the reliability index (2nd survey).

International Journal of Architectural Heritage





Figure 11: Vico del Gargano: comparison between the spatial distribution of masonry types and survey teams.



Figure 12: Vulnerability map of Foggia historical centre (modified ANTAEUS algorithm).



Figure 13: Vulnerability map of Vico del Gargano historical centre (modified ANTAEUS algorithm).



Figure 14: Vulnerability map of Sant'Agata di Puglia historical centre (modified ANTAEUS algorithm).



Figure 15: Vulnerability map of Carlantino historical centre (modified ANTAEUS algorithm).

	In	iternational Jouri	nal of Architectural I	Heritage	
Table 1: Masonry	Buildin	gs: assignment of the vu has been seismi	ulnerability class for Parame cally classified for the first t	ter 1 (Y_c is the year in time).	which the municipality
		М	asonry Buildings		
	Pa	rameter 1 - Type an	d organisation of the re	sisting system	
	RM	Presence	UR. ce of quoins	M No	auoins
Age class		Ring beams or ties	No ring beams nor ties	Ring beams or ties	No ring beams nor ties
$\log class \ge 2008$	А	A	-	-	-
$_{\rm c}$ < age class < 2008	A	B	-	-	-
$ge class \leq Y_c$	В	В	С	С	D

3
1
4
5
6
7
8
9
10
11
10
12
13
14
15
16
17
17
18
19
20
21
22
22
23
24
25
26
27
28
20
29
30
31
32
33
34
35
26
30
37
38
39
40
41
12
42
43
44
45
46
47
48
40 //
49 50
50
51
52
53
54
55
55
30
57
58
59

12

Table 2: Masonry Buildings: assignment of the vulnerability class for Parameter 2.

	Mason	y Buildings	3		
Paramete	Interer 2 - Quality of the resisting system				
Masanwy Tyna	Age 01 c0	nstruction	Rubble In	No hoodore	
Masonry Type	> 1907	<u>≤ 190/</u>	r resence of neaders	No neauers	
M1.3 Regular stone masonry	A	A B	- P	-	
M2.1 Prick masonry	A	D	D	C	
M2 Tuff masonry	A	B	B	C	
$M_1^2 = I u \Pi \Pi a Solir y$	A C	Б	D C		
M1.1 Pubble stone				D	

International Journal of Architectural Heritage

Table 3: Masonry Buildings: assignment of the vulnerability class for Parameter 3.

	gs	
Parameter 3 – Convention	al Capacity	/
	Class	Score
$I_{RV} < 0.15$	A	0
$0.15 \le I_{RV} < 0.45$	B	5
$0.45 \le I_{RV} < 0.70$	C	25
$I_{RV} = 0.70$	D	43

3
4
5
6
7
0
ð
9
10
11
12
13
14
14
15
16
17
18
19
20
20
21
22
23
24
25
26
20
21
28
29
30
31
32
33
22
34
35
36
37
38
30
10
40
41
42
43
44
45
46
40 //7
41
48
49
50
51
52
53
5/
54
55
56
57
58
59

1 2

Table 4: Masonry Buildings: assignment of the vulnerability class for Parameter 4.

Table 5: Masonry Buildings: assignment of the vulnerability class for Parameter 5.

		Masonr	y Buildings			
		Paramet	er 5 - Floors			
	Rigid and w	ell bonded	Well bonded		Poorly b	onded
Floors	Not staggered	Staggered	Not staggered	Staggered	Not staggered	Staggered
O1 – Wooden	A	В	C	D	D	D
O3 – Brick and steel	А	В	С	D	D	D
O2-Brick and concrete	В	С	-	-	D	D
O4 – Vaults with ties	В	С	-	-	-	-
O4 – Vaults without ties	D	D	-	-	-	-

5
6
7
8
9
10
11
12
12
13
14
15
16
17
18
19
20
21
22
~~ ??
23
24
25
26
27
28
29
20
30
31
32
33
34
35
36
37
20
30
39
40
41
42
43
44
45
46
40 //7
41 10
40 40
49
50
51
52
53
54
55
55
56
5/
58
59

Table 6: Masonry Buildings: assignment of the vulnerability class for Parameter 9.

Masonry Buildings								
Parameter 9 - Roofs								
Туре	Ring beams or ties	nusting No ring beams nor ties	Ring beams or ties	No ring beams nor ties	Ring beams or ties	usting No ring beams nor ties		
C1 – Wooden	A	В	В	С	С	D		
C3 – Steel	А	В	В	С	С	D		
C2 – Brick and concrete	В	С	С	D	С	D		
C4 – Vaults		-	-	-	С	D		

International Journal of Architectural Heritage

Table 7: Masonry Buildings: assignment of the vulnerability class for Parameter 10.

International Journal of Architectural Heritage

Table 8: Masonry Buildings: assignment of the vulnerability class for Parameter 11.

Masonry Buildings				
Parameter 11 – Maintenance level				
No damage on roofs and on vertical structures	Α			
Minor damage on roofs or on vertical structures	В			
Minor damage on roofs and on vertical structures	С			
Severe damage on roofs or on vertical structures	D			

2
3
4
5
6
7
8
å
3
10
11
12
13
14
15
16
17
10
10
19
20
21
22
23
24
25
26
20
21
28
29
30
31
32
33
34
35
26
30
37
38
39
40
41
42
43
44
45
40
40
4/
48
49
50
51
52
53
50
54
55
56
57
58

59 60 Table 9: Masonry Buildings: weights and scores of the vulnerability parameters.

Masonry Buildings – scores	and wei	ghting co	efficients		
Parameter	Values of p_i for vulnerability class Weight				
	Α	B	С	D	Wi
1 – Type and organization of the resisting system	0	5	20	45	0.75
2 – Quality of the resisting system	0	5	25	45	0.25
3 – Conventional capacity	0	5	25	45	0.50
4 – Topographic conditions	0	5	25	45	0.50
5 – Floors	0	5	15	45	0.75
6 – In plan configuration	0	5	25	45	0.50
7 – Configuration in elevation	0	5	25	45	1.00
9 – Roofs	0	5	15	45	1.00
10 – Non-structural elements	0	5	25	45	0.25
11 – Maintenance level	0	5	25	45	1.00

ა ⊿
4
5
6
7
8
9
10
11
12
13
14
15
16
17
10
10
19
20
21
22
23
24
25
26
27
28
29
20
21
20
3Z
33
34
35
36
37
38
39
40
41
42
43
44
45
40 46
40 17
47
48
49
50
51
52
53
54
55
56
57
50
50
59

1 2

Table 10: RC buildings: assignment of the vulnerability class for Parameter 1 (B_y = year of construction of the building; Y_c = year of seismic classification of the municipality).

	RC Build	lings				
Parameter 1 – Ty	- Type and organisation of the resisting system					
	Year of construction					
Structural type	$B_y \ge 2008$	$1996 \le B_y < 2008$	$Y_c \le B_y < 1996$	$B_y < Y_c$		
RC2 – RC shear walls	Α	А	В	С		
RC5 – Frames and RC shear walls	A	В	С	D		
RC4 – Frames and strong curtain walls	A	В	С	D		
RC1 – Frames	A	С	С	D		
RC3 – Mixed-structure	-	-	D	D		

3	
4	
4	
5	
6	
7	
8	
0	
9	
10	
11	
12	
13	
1/	
14	
10	
16	
17	
18	
19	
20	
20	
21	
22	
23	
24	
25	
26	
20	
21	
28	
29	
30	
31	
32	
22	
33	
34	
35	
36	
37	
20	
30	
39	
40	
41	
42	
43	
44	
-1-1 1 E	
40	
46	
47	
48	
49	
50	
50	
51	
52	
53	
54	
55	
56	
50	
5/	
58	
59	

60

Table 11: RC buildings: assignment of the vulnerability class for Parameter 2 (B_y = year of construction of the building).

RC Buildings	
Parameter 2 – Quality of the res	isting system
$B_{\mathcal{Y}} \ge 2008$	A
$1992 < B_y < 2008$	В
$1971 < B_y \le 1992$	C
$B_{\gamma} \le 1971$	D

International Journal of Architectural Heritage

Inte	ernational Journal of Architectural	Heritage	Page
Table 12: RC buildings: assi	ignment of the vulnerability class for Parameter	$3 (B_y = \text{year of construction})$	of the building).
	RC Buildings		
	Parameter 3 – Index of Seismic Ra I _{SR}	ating	
	$B_y \ge 2008$	A	
	$1981 < B_y < 2008 \text{ and } I_{SR} \ge 0.3$	В	
	$1981 < B_y < 2008$ and $I_{SR} < 0.3$	С	
	$B_y \leq 1981$	D	
	68		

2	
3	
4	
5	
2	
6	
7	
8	
õ	
3	
10	
11	
12	
12	
13	
14	
15	
16	
47	
17	
18	
19	
20	
20	
21	
22	
23	
24	
24	
25	
26	
27	
21	
28	
29	
30	
21	
51	
32	
33	
34	
25	
30	
36	
37	
38	
00	
39	
40	
41	
12	
40	
43	
44	
45	
16	
40	
47	
48	
49	
50	
50	
51	
52	
53	
55 E 4	
54	
55	
56	
57	
57	
58	
59	

60

Table 13: RC buildings: weights and scores of the vulnerability parameters for RC buildings.

RC Buildings – scores an	d weightin	g coeffi	cients		
Parameter	Values of p_i for vulnerability class Weights				
	Α	B	С	D	Wi
1 - Type and organisation of the resisting system	-10	5	25	45	1.5
2 – Quality of resisting system	-10	5	25	45	1.00
3 – Index of Seismic Rating	-5	5	25	45	0.50
4 – Topographic conditions	0	5	25	45	0.25
6 – In plan configuration	0	5	25	45	0.75
7 – Configuration in elevation	0	5	25	45	0.75
10 – Non-structural elements	0	5	25	45	0.25
11 – Maintenance level	0	5	25	45	0.50

Fog. 100 367 376 1103 128 184 44 46 2348 -0.9	gia 4.3% 15.6% 16,0% 47.0% 5.5% 7.8% 1.9% 2.0%	Vico del 0 31 1 47 306 11 155 1 110 662 -1.5	Muni Gargano 4.7% 0.2% 7.1% 46.2% 1.7% 23.4% 0.2% 16.6%	icipality Sant'Agata d 26 8 48 625 3 15 0 0 725 -0.9	li Puglia 3.6% 1.1% 6.6% 86.2% 0.4% 2.1% 0.0% 0.0%	Carlant 17 215 131 262 7 15 0 3 650 -0.6	ino 3% 33% 20% 40% 1% 2% 0%
Fogg 100 367 376 1103 128 184 44 46 2348 -0.9	gia 4.3% 15.6% 16,0% 47.0% 5.5% 7.8% 1.9% 2.0%	Vico del C 31 1 47 306 11 155 1 110 662 -1.5	Gargano 4.7% 0.2% 7.1% 46.2% 1.7% 23.4% 0.2% 16.6%	Sant'Agata d 26 8 48 625 3 15 0 0 725 -0.9	li Puglia 3.6% 1.1% 6.6% 86.2% 0.4% 2.1% 0.0% 0.0% 0.0%	Carlant 17 215 131 262 7 15 0 3 650 -0.6	ino 3% 33% 20% 40% 1% 2% 0%
100 367 376 1103 128 184 44 46 2348 -0.9	4.3% 15.6% 16,0% 47.0% 5.5% 7.8% 1.9% 2.0%	31 1 47 306 11 155 1 110 662 -1.5	4.7% 0.2% 7.1% 46.2% 1.7% 23.4% 0.2% 16.6%	26 8 48 625 3 15 0 0 725 -0.9	3.6% 1.1% 6.6% 86.2% 0.4% 2.1% 0.0%	17 215 131 262 7 15 0 3 650 -0.6	3% 33% 20% 40% 1% 2% 0%
367 376 1103 128 184 44 46 2348 -0.9	15.6% 16,0% 47.0% 5.5% 1.9% 2.0%	1 47 306 11 155 1 110 662 -1.5	0.2% 7.1% 46.2% 1.7% 23.4% 0.2% 16.6%	8 48 625 3 15 0 0 725 -0.9	1.1% 6.6% 86.2% 0.4% 2.1% 0.0% 0.0%	215 131 262 7 15 0 3 650 -0.6	33% 20% 40% 1% 2% 0%
376 1103 128 184 44 46 2348 -0.9	16,0% 47.0% 5.5% 7.8% 1.9% 2.0%	47 306 11 155 1 110 662 -1.5	7.1% 46.2% 1.7% 23.4% 0.2% 16.6%	48 625 3 15 0 0 725 -0.9	6.6% 86.2% 0.4% 2.1% 0.0% 0.0%	131 262 7 15 0 3 650 -0.6	20% 40% 1% 2% 0%
1103 128 184 44 46 2348 -0.9	47.0% 5.5% 7.8% 2.0%	306 11 155 1 110 662 -1.5	46.2% 1.7% 23.4% 0.2% 16.6%	625 3 15 0 725 -0.9	86.2% 0.4% 2.1% 0.0% 0.0%	262 7 15 0 3 650 -0.6	40% 1% 2% 0%
128 184 44 46 2348 -0.9	5.5% 7.8% 1.9% 2.0%	11 155 1 110 662 -1.5	1.7% 23.4% 0.2% 16.6%	3 15 0 725 -0.9	0.4% 2.1% 0.0% 0.0%	7 15 0 3 650 -0.6	
184 44 46 2348 -0.9	7.8% 1.9% 2.0%	155 1 110 662 -1.5	23.4% 0.2% 16.6%	15 0 0 725 -0.9	2.1% 0.0% 0.0%	15 0 3 650 -0.6	<u>2%</u> 0%
44 46 2348 -0.9	1.9%	1 110 662 -1.5	0.2%	0 0 725 -0.9		0 3 650 -0.6	
46 2348 -0.9	2.0%	110 662 -1.5	16.6%	0 725 -0.9		3 650 -0.6	
<u>2348</u> -0.9	0	<u>662</u> -1.5		725 -0.9		<u>650</u> -0.6	
-0.9	2	-1.5		-0.9		-0.6	

Table 14: Reliability index of the survey forms for the 4 municipalities (4385 total forms).
International Journal of Architectural Heritage

2
3
1
4
5
6
7
, 0
8
9
10
11
11
12
13
14
45
15
16
17
10
10
19
20
21
21
22
23
24
25
20
26
27
28
20
29
30
31
32
32
33
34
35
26
30
37
38
30
59
40
41
42
12
43
44
45
46
17
41
48
49
50
50 E4
51
52
53
51
54
55
56
-

58 59 60 Table 15: Analysis of the reliability index for the City of Foggia.

			<i>j ~ : - j</i>	(City of I	*88)*
Team	Forms	Invalid	Invalid (%)	Avg. IV	Avg. Reliability
1	225	12	5.3%	0.40	-1.05
2	229	19	8.3%	0.44	-1.19
3	217	4	1.8%	0.45	-1.18
4	197	4	2.0%	0.38	-0.96
5	231	11	4.8%	0.44	-0.90
6	247	7	2.8%	0.46	-0.42
7	243	10	4.1%	0.54	-1.26
8	248	27	10.9%	0.44	-1.28
9	238	3	1.3%	0.51	-1.04
10	230	3	1.3%	0.44	-0.25
П	43	0	-	0.44	-0.33
Totale	2348	100	4.3%	0.45	-0.90

71

2
2
4
4
5
6
7
2
8
9
10
11
11
12
13
14
15
10
16
17
18
10
13
20
21
22
22
23
24
25
26
27
21
28
29
30
24
31
32
33
34
25
35
36
37
38
200
39
40
41
42
7 <u>~</u>
43
44
45
16
47
41
48
49
50
50 E1
51
52
53
54
57
22
56
57
58
50
59

1

Table 16: Total number of buildings surveyed with the ANTAEUS form, number of samples for which the GNDT forms were filled in.

Municipality	ANTAEUS	GNDT	Sample %
Foggia	2348	75	3.2
Carlantino	650	25	3.8
Sant'Agata di Puglia	725	25	3.4
Vico del Gargano	662	25	3.7

3
4
4
5
6
7
0
0
9
10
11
40
12
13
14
15
16
10
17
18
19
20
20
21
22
23
24
24
25
26
27
28
20
29
30
31
32
33
33
34
35
36
37
20
38
39
40
41
42
7 <u>7</u> 40
43
44
45
46
17
4/
48
49
50
51
51
52
53
54
55
55
56
57
58
59
~~

60

Table 17: Values of the weights used to calculate the vulnerability index for masonry buildings.

Ma	sonry Buildings		
Parameter	GNDT	GNDT Tuscany	ANTAEUS (1 st proposal)
1 – Type and organization of the resisting system	1.00	1.50	1.50
2 – Quality of resisting system	0.25	0.25	0.25
3 – Conventional resistance	1.50	1.50	0.50
4 – Topographic conditions	0.75	0.75	0.50
5 – Floors	0.5÷1.0 (0.99)	0.5÷1.25 (0.99)	0.75
6 – Configuration in plan	0.50	0.50	0.50
7 – Configuration in elevation	0.5÷1.0 (1.00)	0.5÷1.0 (1.00)	1.00
8 – Maximum distance between the walls	0.25	0.25	-
9 – Roots	$0.5 \div 1.0 (0.59)$	0.5÷1.5 (0.59)	1.00
10 – Non-structural elements	0.25	0.25	0.25

Table 18: Comparison among the results of GNDT, GNDT-Tuscany and ANTAEUS for masonry buildings (all parameters
are weighted and normalized).

A) av 1 2 3 4 5 6 7 7 8 - 9 10 11 Average I.V. Parameter A) av 1 2 3 4 5 6 7 7 8 9 10 11 2 3 4 5 6 7 7 8 9 10 11 2 11 2 11 2 11 2 11 2 11 2 11 2	ANTAEUS average 0.20 0.01 0.03 0.00 0.10 0.02 0.01 - 0.09 0.01 0.02 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	TAEUS GNDT 'age average 0.20 0.12 0.01 0.02 0.03 0.05 0.00 0.00 0.12 0.01 0.03 0.05 0.00 0.00 0.10 0.12 0.01 0.01 0.02 0.01 0.03 0.05 0.01 0.01 0.02 0.01 0.02 0.01 0.49 0.40 Samt FAEUS GNDT average 0.11 0.11	GNDT diff. % 167.30% 28.80% 67.40% - 84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	Tuscany average 0.17 0.02 0.05 0.00 0.11 0.01 0.01 0.01 0.02 0.03 0.04 0.02 0.01 0.02 0.03 0.04 0.02 0.01 0.43 glia	Tuscany diff % 118.40% 30.60% 71.60% - 89.50% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	ANTAEUS average 0.09 0.04 0.07 0.03 0.08 0.03 0.01 0.00 0.12 0.01 0.04	GNDT average 0.09 0.03 0.18 0.02 0.09 0.02 0.00 0.00 0.00 0.04 0.00 0.02	GNDT diff. % 92.10% 123.00% 123.00% 170.50% 92.70% 142.20% 364.10% - 316.60% 303.40%	Tuscany average 0.13 0.03 0.17 0.01 0.09 0.02 0.00 0.00 0.00	Tuscany diff % 65.40% 131.00% 40.70% 185.70% 98.80% 147.10% 333.30% - 333.30%
av 1 2 3 4 5 6 7 8 - 9 10 11 Average I.V. Parameter 1 2 3 4 5 6 7 8 9 10 1 2 3 4 5 6 7 8 9 10 11 Average 1.V.	average 0.20 0.01 0.03 0.00 0.10 0.02 0.01 - 0.09 0.01 0.02 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	'age average 0.20 0.12 0.01 0.02 0.03 0.05 0.00 0.00 0.12 0.01 0.03 0.05 0.00 0.00 0.10 0.12 0.01 0.01 0.02 0.01 0.09 0.05 0.01 0.02 0.02 0.01 0.49 0.40 Samt FAEUS GNDT average 0.11	diff. % 167.30% 28.80% 67.40% - 84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff. %	average 0.17 0.02 0.05 0.00 0.11 0.01 0.01 0.00 0.04 0.02 0.01 0.43 glia	diff % 118.40% 30.60% 71.60% - 89.50% 149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	average 0.09 0.04 0.07 0.03 0.03 0.01 0.00 0.12 0.01 0.04	average 0.09 0.03 0.18 0.02 0.09 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.02	diff. % 92.10% 123.00% 38.40% 170.50% 92.70% 142.20% 364.10% - 316.60% 303.40%	average 0.13 0.03 0.17 0.01 0.09 0.02 0.00 0.00 0.04	diff % 65.40% 131.00% 40.70% 185.70% 98.80% 147.10% 333.30% - 333.30%
1 2 3 4 5 6 7 8 9 10 11 Average I.V. Parameter 1 2 3 4 5 6 7 8 9 10 11 Average 10 11 Average 1.V.	0.20 0.01 0.03 0.00 0.10 0.02 0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.20 0.12 0.01 0.02 0.03 0.05 0.00 0.00 0.10 0.12 0.01 0.12 0.02 0.01 0.01 0.01 0.01 0.01 0.02 0.01 0.03 0.05 0.01 0.01 0.02 0.01 0.02 0.01 0.02 0.01 0.49 0.40 Samt FAEUS GNDT average 0.11 0.11	167.30% 28.80% 67.40% - 84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.17 0.02 0.05 0.00 0.11 0.01 0.01 0.00 0.04 0.02 0.01 0.43 glia	118.40% 30.60% 71.60% - 89.50% 149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.09 0.04 0.07 0.03 0.08 0.03 0.01 0.00 0.12 0.01 0.04 0.51	0.09 0.03 0.18 0.02 0.09 0.02 0.00 0.00 0.00 0.04 0.00 0.02	92.10% 123.00% 38.40% 170.50% 92.70% 142.20% 364.10% - 316.60% 303.40%	0.13 0.03 0.17 0.01 0.09 0.02 0.00 0.00 0.00	65.40% 131.00% 40.70% 185.70% 98.80% 147.10% 333.30% - 333.30%
2 3 4 5 6 7 8 - 9 10 11 Average I.V. Parameter All av 1 2 3 4 5 6 7 8 9 10 11 Average I.V. Parameter 1 All Average I.V. Parameter 1 All Average I.V. Parameter 1 All Average I.V. Parameter 1 All Average I.V. Parameter 1 All Average I.V. Parameter 1 All Average I.V. Parameter 1 All Average I.V. All All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. All Average I.V. Average I.V. Average I.V. Average I.V. All Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V. Average I.V.	0.01 0.03 0.00 0.10 0.02 0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.01 0.02 0.03 0.05 0.00 0.00 0.10 0.12 0.02 0.01 0.01 0.01 0.01 0.01 0.02 0.01 0.09 0.05 0.01 0.02 0.02 0.01 0.02 0.01 0.49 0.40 Sant TAEUS GNDT average 0.11 0.11	28.80% 67.40% - 84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.02 0.05 0.00 0.11 0.01 0.01 0.00 0.04 0.02 0.01 0.43	30.60% 71.60% - 89.50% 149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.04 0.07 0.03 0.08 0.03 0.01 0.00 0.12 0.01 0.04	0.03 0.18 0.02 0.09 0.02 0.00 0.00 0.00 0.04 0.00 0.02	123.00% 38.40% 170.50% 92.70% 142.20% 364.10% - 316.60% 303.40%	0.03 0.17 0.01 0.09 0.02 0.00 0.00 0.04 0.04	131.00% 40.70% 185.70% 98.80% 147.10% 333.30% - 333.30%
3 4 5 6 7 8 9 10 11 1 Average 1.V. Parameter All 2 3 3 6 7 6 7 8 9 10 1 1 2 3 4 5 6 7 8 9 100 10 11 10 Average I.V.	0.03 0.00 0.10 0.02 0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.03 0.05 0.00 0.00 0.10 0.12 0.02 0.01 0.01 0.01 0.09 0.05 0.01 0.02 0.02 0.01 0.09 0.05 0.01 0.02 0.02 0.01 0.49 0.40 Sant FAEUS GNDT average 0.11 0.11	67.40% - 84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.05 0.00 0.11 0.01 0.01 0.00 0.04 0.02 0.01 0.43 glia	71.60% - 89.50% 149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.07 0.03 0.08 0.03 0.01 0.00 0.12 0.01 0.04 0.51	0.18 0.02 0.09 0.02 0.00 0.00 0.00 0.04 0.00 0.02	38.40% 170.50% 92.70% 142.20% 364.10% - 316.60% 303.40%	0.17 0.01 0.09 0.02 0.00 0.00 0.04 0.04	40.70% 185.70% 98.80% 147.10% 333.30% - 333.30%
4 5 6 7 8 9 10 11 Average I.V. Parameter All av 1 2 3 4 5 6 7 8 9 10 11 Average 10 11 Average I.V.	0.00 0.10 0.02 0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.00 0.00 0.10 0.12 0.02 0.01 0.01 0.01 0.00 0.00 0.09 0.05 0.01 0.02 0.02 0.01 0.02 0.01 0.02 0.01 0.49 0.40 Sant FAEUS GNDT average 0.11 0.11	- 84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.00 0.11 0.01 0.00 0.04 0.02 0.01 0.43 glia	89.50% 149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.03 0.08 0.03 0.01 0.00 0.12 0.01 0.04	0.02 0.09 0.02 0.00 0.00 0.04 0.00 0.02	170.50% 92.70% 142.20% 364.10% - 316.60% 303.40%	0.01 0.09 0.02 0.00 0.00 0.04 0.04	185.70% 98.80% 147.10% 333.30% - 333.30%
5 6 7 8 9 10 11 Average I.V. Parameter All 2 3 4 5 6 7 8 9 10 11 Average 10 11 Average I.V.	0.10 0.02 0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.10 0.12 0.02 0.01 0.01 0.01 0.00 0.00 0.09 0.05 0.01 0.02 0.02 0.01 0.49 0.40 Sant TAEUS GNDT age average 0.11 0.11	84.30% 141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.11 0.01 0.00 0.04 0.02 0.01 0.43 glia	89.50% 149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.08 0.03 0.01 0.00 0.12 0.01 0.04	0.09 0.02 0.00 0.00 0.04 0.00 0.02	92.70% 142.20% 364.10% - 316.60% 303.40%	0.09 0.02 0.00 0.00 0.04 0.00	98.80% 147.10% 333.30% - 333.30%
6 7 8 9 10 11 Average I.V. Parameter Al av 1 2 3 4 5 6 7 8 9 10 11 Average 1.V.	0.02 0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.02 0.01 0.01 0.01 0.00 0.00 0.09 0.05 0.01 0.02 0.02 0.01 0.49 0.40 Sant FAEUS GNDT average 0.11 0.11	141.10% 206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.01 0.01 0.00 0.04 0.02 0.01 0.43 glia	149.80% 219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.03 0.01 0.00 0.12 0.01 0.04	0.02 0.00 0.00 0.04 0.00 0.02	142.20% 364.10% - 316.60% 303.40%	0.02 0.00 0.00 0.04 0.00	147.10% 333.30% - 333.30%
7 8 9 10 11 Average I.V. Parameter Al av 1 2 3 4 5 6 7 8 9 10 11 Average I.V.	0.01 - 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.01 0.01 0.00 0.00 0.09 0.05 0.01 0.02 0.02 0.01 0.49 0.40 Samt FAEUS GNDT average 0.11 0.11	206.20% 0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.01 0.00 0.04 0.02 0.01 0.43 glia	219.00% 0.00% 199.50% 63.40% 194.50% 112.50%	0.01 0.00 0.12 0.01 0.04	0.00 0.00 0.04 0.00 0.02	364.10% - 316.60% 303.40%	0.00 0.00 0.04 0.00	333.30% - 333.30%
8 - 9 10 11 Average I.V. Parameter 4 Average 5 6 7 8 9 10 10 11 Average 1.V.	- 0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.00 0.09 0.05 0.01 0.02 0.01 0.49 0.40 Sant TAEUS GNDT average 0.11 0.11	0.00% 187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.00 0.04 0.02 0.01 0.43 glia	0.00% 199.50% 63.40% 194.50% 112.50%	0.00 0.12 0.01 0.04	0.00 0.04 0.00 0.02	- 316.60% 303.40%	0.00	- 333.30%
9 10 11 Average I.V. Parameter average 1 2 3 4 5 6 7 8 9 10 11 Average I.V.	0.09 0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.09 0.05 0.01 0.02 0.02 0.01 0.49 0.40 Sant FAEUS GNDT rage average 0.11 0.11	187.90% 59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.04 0.02 0.01 0.43 glia	199.50% 63.40% 194.50% 112.50%	0.12 0.01 0.04	0.04 0.00 0.02	316.60% 303.40%	0.04	333.30%
10 11 Average I.V. Parameter Al av 1 2 3 4 5 6 7 8 9 10 11 Average I.V.	0.01 0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.01 0.02 0.02 0.01 0.49 0.40 TAEUS GNDT rage average 0.11 0.11	59.70% 183.20% 121.60% 'Agata di Pu GNDT diff, %	0.02 0.01 0.43 glia	63.40% 194.50% 112.50%	0.01 0.04	0.00 0.02	303.40%	0.00	
11 Average I.V. Parameter A) av 1 2 3 4 5 6 7 8 9 10 11 Average I.V.	0.02 0.49 ANTAEUS average 0.11 0.03 0.05	0.02 0.01 0.49 0.40 Sant TAEUS GNDT average 0.11 0.11	183.20% 121.60% Agata di Pu GNDT diff. %	0.01 0.43 glia	194.50% 112.50%	0.04	0.02		0.00	333.30%
Average I.V. Parameter Al av 1 2 3 4 5 6 7 8 9 10 11 Average I.V.	0.49 ANTAEUS average 0.11 0.03 0.05	0.49 0.40 Sant FAEUS GNDT rage average 0.11 0.11	121.60% 'Agata di Pu GNDT diff. %	0.43 glia	112.50%	0.51		197.60%	0.02	211.10%
Parameter All av av 1 1 2 1 3 1 4 1 5 1 6 1 7 2 8 1 9 1 10 11 Average I.V.	ANTAEUS average 0.11 0.03 0.05	Sant FAEUS GNDT rage average 0.11 0.11	'Agata di Pu GNDT diff. %	glia		0.51	0.49	102.80%	0.51	99.60%
Al av 1 2 3 4 5 6 7 7 8 9 10 11 Average I.V.	ANTAEUS average 0.11 0.03 0.05	FAEUSGNDT cageaverage0.110.11	GNDT diff. %					Carlantino		
av 1 2 3 4 5 6 7 8 9 10 11 Average I.V.	average 0.11 0.03 0.05	rage average 0.11 0.11	diff. %	Tuscany	Tuscany	ANTAEUS	GNDT	GNDT	Tuscany	Tuscany
1 2 3 4 5 6 7 8 9 10 11 Average I.V.	0.11 0.03 0.05	0.11 0.11		average	diff %	average	average	diff. %	average	diff %
2 3 4 5 6 7 8 9 10 11 Average I.V.	0.03 0.05	0.00	97.50%	0.16	69.20%	0.10	0.11	84.80%	0.16	60.00%
3 4 5 6 7 8 9 10 11 Average I.V.	0.05	0.03 0.03	101.70%	0.03	109.30%	0.02	0.03	64.70%	0.03	68.70%
4 5 7 8 9 10 11 Average I.V.		0.05 0.18	28.60%	0.17	30.30%	0.03	0.18	15.20%	0.17	16.10%
5 6 7 8 9 10 11 11 Average I.V.	0.07	0.07 0.03	222.60%	0.03	238.40%	0.07	0.03	218.50%	0.03	232.00%
0 7 8 9 10 11 Average I.V.	0.12	0.12 0.12	97.80%	0.11	104.00%	0.11	0.12	93.00%	0.11	98.70%
8 9 10 11 Average I.V.	0.01	0.01 0.01	181.10%	0.01	203.50%	0.03	0.01	313.90%	0.01	333.30%
9 10 11 Average I.V.	0.02	0.02 0.01	338.70%	0.01	348.90%	0.01	0.01	197.00%	0.01	209.80%
10 11 Average I.V.	0.00	0.00 0.00	220.60%	0.00	234 40%	0.00	0.00	-	0.00	-
II Average I.V.	0.14	0.14 0.00	56.40%	0.00	58 10%	0.09	0.00	36.20%	0.00	38 50%
Average I.V.	0.03	0.01 0.01	148 20%	0.02	153 40%	0.04	0.01	177 70%	0.01	188 70%
I.V.	0.05	0.05 0.02	140.2070	0.02	155.4070	0.04	0.02	177.7070	0.02	100.7070
	0.58	0.58 0.58	101.00%	0.60	97.80%	0.49	0.58	84.00%	0.60	81.30%

3	
4	
5	
6	
7	
0	
0	
9	
10	
11	
12	
13	
14	
14	
15	
16	
17	
18	
19	
20	
20 04	
21	
22	
23	
24	
25	
26	
27	
20	
28	
29	
30	
31	
32	
33	
34	
25	
35	
36	
37	
38	
39	
40	
/1	
40	
42	
43	
44	
45	
46	
47	
48	
40 70	
49 50	
50	
51	
52	
53	
54	
55	
55	
50	
5/	
58	
59	

60

Table 19: Statistics for masonry buildings - comparison between weighted averages obtained by ANTAEUS algorithm.

I.V. St. dev I.V. St. dev Foggia 0.49 0.09 0.45 0.10 Vico del Gargano 0.53 0.12 0.51 0.11 Sant'Agata 0.59 0.09 0.56 0.08 Carlantino 0.50 0.10 0.46 0.09
Foggia 0.49 0.09 0.45 0.10 Vico del Gargano 0.53 0.12 0.51 0.11 Sant'Agata 0.59 0.09 0.56 0.08 Carlantino 0.50 0.10 0.46 0.09
Vico del Gargano 0.53 0.12 0.51 0.11 Sant'Agata 0.59 0.09 0.56 0.08 Carlantino 0.50 0.10 0.46 0.09
Sant'Agata 0.59 0.09 0.56 0.08 Carlantino 0.50 0.10 0.46 0.09
Carlantino 0.50 0.10 0.46 0.09