



# Politecnico di Bari

Repository Istituzionale dei Prodotti della Ricerca del Politecnico di Bari

Dealing with a cluster of large centralized municipal wastewater treatment plants: A case study

This is a pre-print of the following article

*Original Citation:*

Dealing with a cluster of large centralized municipal wastewater treatment plants: A case study / De Gisi, Sabino; Pica, Raffaele; Casella, Patrizia; Notarnicola, Michele. - In: PROCESS SAFETY AND ENVIRONMENTAL PROTECTION. - ISSN 0957-5820. - STAMPA. - 118:(2018), pp. 268-278. [10.1016/j.psep.2018.07.002]

*Availability:*

This version is available at <http://hdl.handle.net/11589/136267> since: 2021-03-31

*Published version*

DOI:10.1016/j.psep.2018.07.002

*Terms of use:*

(Article begins on next page)

1 **DEALING WITH A CLUSTER OF LARGE CENTRALIZED MUNICIPAL**  
2 **WASTEWATER TREATMENT PLANTS. A CASE STUDY**

3

4 Sabino De Gisi<sup>1,\*</sup>, Raffaele Pica<sup>2</sup>, Patrizia Casella<sup>3</sup>, Michele Notarnicola<sup>1</sup>

5

6 <sup>1</sup> Department of Civil, Environmental, Land, Building Engineering and Chemistry (DICATECh), Polytechnic  
7 University of Bari, Via E. Orabona n.4, 70125 Bari (BA), ITALY

8 <sup>2</sup> ENEA, Italian National Agency for New Technologies, Energy and Sustainable Economic Development,  
9 ENEA, USER-R4R Lab., Via Martiri di Monte Sole 4, 40129 Bologna (BO), ITALY

10 <sup>3</sup> ENEA, Italian National Agency for New Technologies, Energy and Sustainable Economic Development.  
11 Department of Sustainability, P.zza E. Fermi, 80055 Portici (NA), ITALY

12

13 **ABSTRACT**

14

15 The article deals with a cluster of large centralized municipal wastewater treatment plants  
16 (LCMWWTPs) assessing the main economic, energy, environmental and management  
17 aspects. With reference to the case study of the Regi Lagni system (Southern Italy),  
18 composed of five WWTPs for an overall effective population of 2,235,800 inhabitants the  
19 study focused first on the multi-disciplinary characterization of the system investigated and  
20 then on potential future upgrading options, identifying the best suitable solution. For the  
21 scope, several indicators such as running costs, energy consumptions, Greenhouse Gas  
22 Emissions (GHG), sludge for landfilling and two scenarios were defined. The first scenario  
23 focused on the role of anaerobic digestion while the dewatered sludge was sent to landfill.  
24 The second scenario implemented the same operations of the previous one although the  
25 construction of a thermal treatment plant for the dewatered sludge was also planned.  
26 Results showed how LCMWWTPs could be characterised by low resilience; the upgrading

\*Address correspondence to:

**Sabino De Gisi**, Department of Civil, Environmental, Land, Building Engineering and Chemistry (DICATECh),  
Polytechnic University of Bari, Via E. Orabona n.4, 70125 Bari (BA), ITALY; e-mail: sabino.degisi@poliba.it

27 of plants to comply with the increasingly stringent legal limits was difficult, especially  
28 where works were carried out to ensure continuity of operation. Multi-criteria analysis  
29 allowed the cluster system based on anaerobic digestion to be the best solution from an  
30 economic, energy and environmental point of view.

31

32 **Keywords:** Energy consumption, GHG emissions, Regi Lagni, running costs, sludge  
33 management, wastewater engineering

34

## 35 1. INTRODUCTION

36

37 Wastewater treatment approaches vary from traditional centralised systems to fully  
38 decentralised on-site systems. Centralized systems, usually publicly owned, collect and  
39 treat large volumes of wastewater for large communities (Crites and Tchobanoglous, 1998;  
40 Massoud *et al.*, 2009). Conversely, decentralised on-site systems treat wastewater from  
41 individual homes and buildings (Brown *et al.*, 2009). Between these two extremes, there  
42 are other intermediate treatment systems as reported in Libralato *et al.* (2012), and herein  
43 described.

44 Centralization consists of a sewer system collecting wastewater that is conveyed to a  
45 wastewater treatment plant (WWTP) generally located outside of the limits of the city  
46 (Wilderer and Schreff, 2000). Centralization has been the most widely adopted design  
47 solution in the previous century and has also been tackled systematically on a scientific  
48 level (International Water Association (IWA) specialist group on design, operation and  
49 costs of large wastewater treatment plants). The Satellite Treatment Plant (STP) facilities  
50 are integrated with centralised systems for solids processing. The sludge produced by the  
51 purification treatment of isolated houses, for example by septic tanks or Imhoff tanks, is

52 transported with tankers to centralized plants equipped with dedicated pre-treatment  
53 (Libralato *et al.*, 2012; Lee *et al.*, 2018). The Semi-centralised supply and treatment  
54 systems (SESATS) is used for villages and suburbs that cannot always be connected to  
55 centralized sewer systems and treatment plants as well as when pumping stations and  
56 transfer pipelines are cost-prohibitive (Weber *et al.*, 2007). The arriving wastewater is first  
57 mechanically pre-treated in a compact plant with integrated fine screen and grit/grease  
58 chamber; after intermediate storage, wastewater is treated full-biologically in a compact  
59 reactor. In the Great Block system, wastewater from individual buildings (i.e., schools) can  
60 be managed with complete recycle systems (Libralato *et al.*, 2012). It represents a highly  
61 useful solution for arid and semi-arid areas such as the Mediterranean countries; the  
62 recovery of rainwater and the treatment of grey water also for their reuse reduces the  
63 demand for drinking water (Lazarova *et al.*, 2003; De Gisi *et al.*, 2016). In the cluster  
64 systems, typically, 4 to 12 or more houses are grouped to form a cluster system for  
65 improved wastewater management (Brown *et al.*, 2009; Libralato *et al.*, 2012). Cluster  
66 systems are favourable in areas that are more densely populated or that have poor soil  
67 conditions and adverse topography. Finally, in the individual system, the treatment is  
68 carried out at home level; different schemes are available such as the NoMix approach  
69 where urine and faeces are separated directly at source via an ad hoc WC (McCann, 2010;  
70 De Gisi *et al.*, 2014a).

71 Each system certainly has its own advantages and disadvantages. Several studies have  
72 investigated these advantages, criticisms and limitations considering social, economic and  
73 environmental issues (Wilderer and Schreff, 2000; Massoud *et al.*, 2009; Libralato *et al.*,  
74 2012; Yung *et al.*, 2018). Although the present world seems to be moving towards  
75 decentralised systems, mainly due to significant investments to upgrade facilities at the end  
76 of their life cycle, it resulted that none of the approaches could be excluded a priori;

77 generally, the different systems can be integrated with each other on the basis of the  
78 specific required situation (Wilderer and Schreff, 2000; Libralato *et al.*, 2012).

79 The above classification of treatment systems did not take into account that in some  
80 territories the concept of centralization was so extended that a cluster of large centralized  
81 WWTPs was constructed. In general, the term “cluster” refers to a grouping of  
82 interconnected WWTPs; the joint management of sludge, which is also facilitated by the  
83 presence of a single water service operator, is an example of relationship between the  
84 WWTPs in the cluster. In such a cluster, in order to optimise the system’s costs/revenues,  
85 the operation of the individual plants was integrated; the flows of one plant (i.e., sludge)  
86 were linked to those of another plant.

87 Although the literature on the topic was extensive, there is very little information about a  
88 cluster of large centralized WWTPs. However, the study of a cluster of this type can  
89 provide useful information on important aspects such as the resiliency of WWTPs,  
90 understood as the ability of the plant to comply with substantial changes (i.e., new inlet  
91 organic loads, the need to meet more stringent discharge limit values), or whether, at the  
92 end of their life cycle, what is the most sustainable upgrading scenario. These issues are  
93 particularly relevant in view of the considerable investments that will be made in the next  
94 few years in renovating the integrated water system (De Gisi *et al.*, 2014b; Dürrenmatt and  
95 Wanner, 2014).

96 Thus, the aim of the paper was to study a cluster of large centralized municipal WWTPs  
97 assessing the main economic, energy, environmental and management aspects. With  
98 reference to the case study of the Regi Lagni system (Southern Italy), composed of 5 large  
99 WWTPs for an overall potentiality of 2,235,800 effective populations equivalent (where,  
100 PE corresponds to a five-day biodegradable organic load of 60 g BOD<sub>5</sub>/d), the study  
101 focused first on the multi-disciplinary characterization of the cluster investigated and then

102 on potential future technological and management upgrading options; in this way it was  
103 possible to discuss the best suitable solution from an energy, economic and environmental  
104 point of view. Performance evaluation involved the use of various sources; in the case of  
105 the estimation of the Greenhouse Gas (GHG) emissions produced by a WWTP, the free-  
106 available ECAM (Energy Performance and Carbon Emissions Assessment and  
107 Monitoring) 2.0 tool was used (<http://wacclim.org/ecam-tool/>). The assessment of the  
108 impact of each plant on the receiving water body, the estimate of costs and energy  
109 consumption, of waste produced by the cluster of WWTPs, where not directly supplied by  
110 the operator, was carried out on the basis of the indications contained in Teodosiu *et al.*  
111 (2015), De Gisi *et al.* (2015) and Sabia *et al.* (2016), respectively.

112

## 113 **2. METHODOLOGICAL APPROACH**

114

### 115 *2.1 Case study description*

116 The Regi Lagni system was an ancient hydraulic reclamation structure, essentially made up  
117 of a network of canals dug into the land to drain the waters of an often marshy territory,  
118 extending about 100,000 hectares in the productive heart of the provinces of Naples and  
119 Caserta (ENEA, 2010a). The canal works, started in Roman times, saw a strong  
120 commitment to the hydraulic reorganization during the Spanish Viceregnato at the beginning  
121 of 1600. The reclamation had put an end to the centuries-old problem of the flooding of the  
122 *Clanio* stream in “Campania Felix” and mitigated malaria in the hinterland. In 1973, the  
123 choleric infection that affected the area of Naples justified the beginning of very heavy  
124 interventions of urgent hygienic sanitary reorganization of the area. Five large centralised  
125 municipal WWTPs were realized, which discharge directly into the main channel of the  
126 Regi Lagni system (Fig. 1).

127

128 **Figure 1. The anthropic basin of the Regi Lagni system: (a) Hydrographic sub-basins;**  
129 **(b) Main river and the 5 large WWTPs.**

130

131 The treatment plants were supposed to “once and for all” clean up the sanitation situation  
132 of the drainage water and allow the bathing of the waters north of Naples. The construction  
133 of the WWTPs was financed by the Italian Government through the Cassa del  
134 Mezzogiorno, as part of the “Progetto Speciale n. 3 per il disinquinamento del Golfo di  
135 Napoli” (De Feo *et al.*, 2009).

136 The five WWTPs, having been built in compliance with the rules and design criteria in  
137 force in the 1970s, were inadequate to date; the plant structures and equipment have  
138 become obsolete and the new environmental regulations have imposed stricter limits. In  
139 this respect, Table 1 showed how the PE of today ( $PE_{\text{eff}} = \text{PE}$  effectively served by the  
140 WWTP) were different from the project one ( $PE_{\text{des}} = \text{PE}$  related to the project  
141 configuration); Acerra, Foce Regi Lagni and Napoli Nord WWTPs were oversized  
142 compared to current requirements ( $PE_{\text{eff}}/PE_{\text{des}} \ll 100\%$ ); on the other hand, the Area  
143 Nolana and Area Casertana WWTPs were overloaded by 130.5% and 106.5%,  
144 respectively.

145

146 **Table 1. The “Regi Lagni” system wastewater treatment plants (re-elaborated Pica *et***  
147 ***al.*, 2016).**

148

149 The inlet organic load, expressed as BOD<sub>5</sub> concentration (BOD = Biochemical Oxygen  
150 Demand at five days), classified wastewater as medium (around 200 mg/l) and high  
151 composition (300 mg/l). Instead, TSS concentrations (TSS = Total Suspended Solids) were

152 in most cases less than 350 mg/l and therefore of low composition. Total nitrogen (TN)  
153 concentrations made it possible to classify wastewater with a medium (around 40 mg/l)  
154 and high (around 85 mg/l) nitrogen composition.

155 The values of the BOD<sub>5</sub>/NH<sub>4</sub>-N ratios showed a low ability to remove nitrogen compounds  
156 by conventional denitrification and nitrification processes (Tab. 1).

157 The five WWTPs were designed according to the full-treatment scheme, thus equipped  
158 with primary sedimentation, activated sludge-based oxidation and anaerobic digestion. In  
159 addition, due to the high overall PE ( $PE_{des} = 800,000$ ), a thermal treatment plant for  
160 dewatered sludge was also built at the Area Casertana WWTP.

161 Data from Pica *et al.* (2016), referring to the 2010 context, showed a different state of  
162 quality of the plants and its Unit of Process (UoPs) (Tab. 2), although managed by the  
163 same operator. The Area Nolana and Area Casertana WWTPs showed a good quality.

164

165 **Table 2. Treatment schemes and status of the unit of process (UoP) (re-elaborated**  
166 **Pica *et al.*, 2016).**

167

168 With the exception of the Area Casertana WWTP, everyone had problems with the sludge  
169 line; anaerobic digestion, one of the most delicate processes in the plant, was out of  
170 service. Nitrogen removal processes, with the exception of the Area Nolana WWTP, had  
171 not been implemented.

172 The “desolate” situation described above had legal and political implications; in many  
173 cases, some WWTPs had been confiscated by the Competent Authority, precisely because  
174 of frequent violations of environmental protection laws.

175

176 *2.2 Methodology for assessing WWTPs cluster performance*



177 The methodological approach provided first for the evaluation of the performance of the  
178 Regi Lagni system (or cluster) in its current configuration and then for the evaluation of  
179 the cluster, having hypothesized different technological solutions for WWTPs upgrading.  
180 Because of the complexity of the problem, a multi-criteria approach was adopted.  
181 By referring to the cluster boundary, the following indicators were identified and  
182 quantified (the so called *system-indicators*): (I<sub>1C</sub>) Energy consumption, (I<sub>2C</sub>) GHG  
183 emissions production, (I<sub>3C</sub>) Wastes for landfilling, (I<sub>4C</sub>) Running costs, (I<sub>5C</sub>) Impact on the  
184 receiving water body. In detail, I<sub>1C</sub> measured the consumption of electricity from the  
185 national grid for the WWTPs operation. I<sub>2C</sub> quantified the GHG emissions produced by the  
186 treatment processes. I<sub>3C</sub> considered the total waste produced by the 5 WWTPs, which in  
187 turn consisted of screening waste, sand, oil, greases and sludges. I<sub>4C</sub> quantified the running  
188 costs of the plants while I<sub>5C</sub> measured the overall impact of the 5 WWTPs on the receiving  
189 water body. These indicators work on a cluster scale.  
190 However, their quantification included an evaluation at the scale of each WWTP. For  
191 example, considering the I<sub>1C</sub> indicator, its value at cluster scale was calculated as the sum  
192 of the energy consumption of each WWTP (I<sub>1WWTPi</sub>):  $I_{1C} = \sum I_{1WWTPi}$  with  $i = 1, \dots, 5$ . The  
193 same approach was followed for the remaining indicators (I<sub>2C</sub>-I<sub>4C</sub>). The I<sub>5C</sub> indicator is  
194 detailed subsequently.  
195 Finally, in order to compare the proposed technology upgrading scenarios, a composite  
196 indicator was constructed. The most important elements of the multi-criteria approach are  
197 illustrated below.

198

### 199 2.2.1 Evaluation database

200 The data used in the study and shown in tables 1 and 2 were part of a broader study  
201 conducted by ENEA in 2010 under the “Regi Lagni project” (ENEA, 2010b). For each

202 plant, there was a detailed report showing the performance in terms of pollutant removal  
203 and the quality status of the process units; reports were available online (ENEA, 2010a).  
204 Instead, the determination of energy and environmental performance, running costs as well  
205 as the quantity of dewatered sludge produced by the plants, where the previous reports  
206 were lacking in terms of data (Tab. 3), was done according to the methodologies and  
207 databases described below.

208

209 **Table 3. Input data availability for the evaluation of the current cluster.**

210

211 *2.2.1.1 Energy*

212 The energy consumption of a municipal WWTP was assessed on the basis of the unit  
213 values of the consumption of each UoP. With reference to the data reported in Campanelli  
214 *et al.* (2013) and at 1 m<sup>3</sup> of inlet wastewater in the plant, the following values were  
215 assumed: 0.07 kWh/m<sup>3</sup> for initial pumping (Archimedes screw, centrifugal pumps); 0  
216 kWh/m<sup>3</sup> for the screening (coarse and fine, compaction); 0.02 kWh/m<sup>3</sup> for the sand and  
217 oils removal (air blower, crane bridge movement, extraction pump and air lift); 0.05  
218 kWh/m<sup>3</sup> for (pre)denitrification (mixer); 0.38 kWh/m<sup>3</sup> for oxidation of the  
219 carbon/nitrification fraction (air diffusion system); 0.095 kWh/m<sup>3</sup> for recirculation of the  
220 mixed liquor (pump); 0.025 kWh/m<sup>3</sup> for the return activated sludge recirculation (pump);  
221 0.01 kWh/m<sup>3</sup> for secondary sedimentation (movement of the bridge crane); 0 kWh/m<sup>3</sup> for  
222 filtration; 0 kWh/m<sup>3</sup> for extraction of primary and secondary sludge (pumps); 0.015  
223 kWh/m<sup>3</sup> for the aerobic stabilisation of sludge (mixing system); 0.015 kWh/m<sup>3</sup> for the  
224 mechanical dewatering of the sludge.

225 The above data showed a zero value for some UoP and therefore the energy consumption  
226 was negligible.

227 Energy production from anaerobic digestion was assessed, in the absence of site-specific  
228 data, according to Metcalf and Eddy (2003), by adopting a specific daily production of 20  
229 l/PE/d, corresponding to about 0.075 Nm<sup>3</sup> of biogas per 1 m<sup>3</sup> of wastewater. This was a  
230 “prudential” value, slightly lower than that reported in the literature (Metcalf and Eddy,  
231 2003) for an anaerobic digester operating under mesophilic condition (20-40 l/PE/d). With  
232 reference to a biogas with a methane content (CH<sub>4</sub>) of 60% and an electric motor  
233 efficiency of 30% (for the conversion of biogas into electrical energy), a specific electric  
234 energy production of 1.6 kWh/Nm<sup>3</sup> of biogas was assumed (Campanelli *et al.*, 2013).  
235 The energy requirements of each WWTP therefore took into account both the energy  
236 consumed in the plant and the self-produced energy used for internal uses.

237

#### 238 2.2.1.2 GHG emissions

239 The evaluation of the GHG emissions produced by the single WWTP involved the use of  
240 ECAM 2.0, a tool developed as part of the WaCCliM project ([http://wacclim.org/ecam-](http://wacclim.org/ecam-tool/)  
241 [tool/](http://wacclim.org/ecam-tool/)).

242 ECAM considered three types of GHG emissions: direct greenhouse gas emissions;  
243 indirect GHG emissions associated with grid electricity consumption; all other indirect  
244 emissions. Direct emissions included (i) emissions from the maintenance trucks, (ii) CO<sub>2</sub>  
245 (carbon dioxide), CH<sub>4</sub> and NO<sub>2</sub> (nitrogen dioxide) emissions from on-site stationary fossil  
246 fuel combustion, (iii) CH<sub>4</sub> and (iv) NO<sub>2</sub> from sewers or biological wastewater treatment.

247 The other indirect emissions, instead, included (i) emissions from manufacturing of  
248 chemical used, (ii) emissions from the construction materials used, (iii) CH<sub>4</sub> and NO<sub>2</sub> from  
249 wastewater discharge without treatment, (iv) CO<sub>2</sub>, CH<sub>4</sub> and N<sub>2</sub>O from sludge transport off-  
250 site and (v) NO<sub>2</sub> from effluent discharge in receiving waters. Other emissions, such as end-  
251 user emissions or CO<sub>2</sub> produced by microbial rupture of organic matter in activated sludge

252 reactors (considered to be a source of biogenic nature, although the literature is  
253 controversial on this point), were not included in ECAM (ECAM 2.0 manual, 2017).

254 The environmental assessment was carried out on an annual basis. With reference to the  
255 Italian situation, the values of “Emission factor for grid electricity”, “Annual protein  
256 consumption per capita” and “BOD<sub>5</sub> per person per day” were assumed of 0.410898038  
257 kgCO<sub>2</sub>/kWh, 40.88 kg/person/year e 60 g/person/day, respectively (provided by default by  
258 the tool, that allows only the country to be selected). The IPCC 5th AR (2014/2013) CCF  
259 was selected as “Global Warming Potential (GWP) source”. The GWP values relative to  
260 CO<sub>2</sub> for a 100-year time horizon were: CO<sub>2</sub> = 1 CO<sub>2</sub> equivalents; CH<sub>4</sub> = 34 CO<sub>2</sub>  
261 equivalents; N<sub>2</sub>O = 298 CO<sub>2</sub> equivalents.

262 ECAM also allowed to define the typology (i.e., activated sludge) and the functioning  
263 (well-managed, minor poorly aerated zones, some aerated zones, not well managed) of the  
264 biological treatment implemented in the plant as well as the sludge disposal method  
265 (composting, incineration, land application, landfilling and stockpiling). In this specific  
266 case, the landfill was the final destination of the sludge, which, once mechanically  
267 dewatered, was transported by means of transport to landfills for special waste.

268 Furthermore, evaluation with ECAM takes place at two stages, indicated *Tier A* and *Tier B*.  
269 The first (*Tier A*) allowed a preliminary evaluation of WWTP performance in terms of  
270 GHG emissions and energy consumed; as an input, several parameters were to be  
271 provided, as following reported: PE, energy consumed from the grid, volume of fuel  
272 consumed, volume of treated wastewater, volume of discharged wastewater to water body,  
273 running costs, energy costs, average Total Nitrogen (TN) at discharge, if you are producing  
274 biogas and/or if you are valorising biogas, the main treatment type (i.e., activated sludge,  
275 trickling filter, etc.) as well as the sludge disposal method (composting, incineration,  
276 landfilling, etc.). Instead, the *Tier B* offered a detailed assessment. In addition to the

277 previous parameters, as the data input it was necessary to add the influent and effluent  
278 BOD load, the BOD removed as sludge, the BOD mass removed, if used, the type of fuel  
279 engines (i.e., methane) as well as the volume of fuel consumed. Furthermore, many other  
280 requests composed the so-called “advanced assessment” modules.

281 In this study, the GHG emissions were estimated with the *Tier B*.

282

### 283 *2.2.1.3 Running costs*

284 The running costs considered in the study related to the cost of (i) electricity, (ii) operating  
285 personnel and (iii) technical/managerial ones, (iv) reagents (sodium hypochlorite or  
286 peracetic acid for disinfection, ferric chloride or polyelectrolyte for sludge conditioning),  
287 disposing of (v) screening by-products (European Waste Code – EWC 19 08 01), (vi) oils  
288 and greases (EWC code 19 08 09), (vii) sands (EWC code 19 08 02), (viii) sludge (EWC  
289 code 19 08 05) and (ix) for maintenance. The unit cost of operating and technical  
290 personnel was 3.78 and 1.65 €/PE, in line with the literature related to large facilities (PE >  
291 200,000) (De Feo *et al.*, 2012) as well as the values provided directly by the operator.

292 For reagents, values of 0.35 and 0.24 €/PE were assumed respectively for disinfectant and  
293 chemical used for sludge conditioning. The unit cost for the disposal of screening by-  
294 products and sand was 138 €/t; the cost for the disposal of oils and greases and for sludge  
295 was 100 and 200 €/t, respectively. The unit cost of electricity, both consumed and  
296 produced, was assumed to be 0.12 €/kWh.

297 The current cost, calculated as the sum of the above items (De Gisi *et al.*, 2015), was then  
298 increased by 10% to take account of general expenses and VAT (value-added tax).

299

### 300 *2.2.1.4 Wastes for landfilling*

301 The calculation of the wastes for landfilling required the prior identification of the system

302 boundary which, in the case of a single WWTP, coincided with the physical boundary of  
303 the plant. In the absence of site-specific data, sludge production was estimated (primary  
304 and secondary) using the methodology reported in Sabia *et al.* (2016). The sludge from the  
305 plant was then sent to landfill via trucks. Taking into account that the sludge produced in  
306 the Regi Lagni system has long been sent to Apulia Region (De Feo *et al.*, 2017), a  
307 distance of 300 km was assumed between the centre of gravity of the basin and the landfill.

308

#### 309 2.2.1.5 Environmental impact on water body

310 The environmental impact of the WWTPs cluster was calculated considering the  
311 environmental impact assessment methodology reported in Teodosiu *et al.* (2015). In  
312 particular, considering the single WWTP, the environmental impact (EI) on the water body  
313 was estimated with the following relation:

314

$$EI = \frac{C_{det} \cdot q_{det}}{C_{max} \cdot q_{max}} \cdot IU \quad (1)$$

315

316 where  $q_{det}$  was the average wastewater flow discharged by the pollution source (measured  
317 value),  $m^3/s$ ;  $q_{max}$  was maximum contracted wastewater flow, according to the  
318 environmental permit,  $m^3/s$ ;  $C_{det}$  was the average pollutant concentration (as given by a  
319 specific water quality indicator) in the effluent,  $mg/L$ ;  $C_{max}$  was the maximum allowed  
320 concentration (MAC) for wastewater discharging into natural receivers,  $mg/L$ ; IU  
321 importance unit (dimensionless).

322 Based on the available data, three common water quality indicators were used: BOD<sub>5</sub>, TSS  
323 and TN. The maximum allowed concentrations, MAC, referred to the discharge limits  
324 imposed by Italian Law (D.Lgs 152/2006): BOD<sub>5</sub> = 25  $mg/l$ ; TSS = 35  $mg/l$ ; TN = 15

325 mg/l.

326 The importance units (IU), that in accordance to Teodosiu *et al.* (2015) was introduced in  
327 the method as an expression of the impact of the polluter upon the state of the receiving  
328 water body, was evaluated on the basis of the data available at the time of the assessment  
329 (year 2010). In this regard, the Campania regional environmental protection agency  
330 (ARPAC) classified all the sections of the Regi Lagni river as belonging to the fifth class  
331 of the chemical status (ARPA, 2010). According to the Water Framework Directive (EC,  
332 2000), the fifth class had a “bad” meaning and as consequence, the river waters were  
333 highly contaminated. Based on Teodosiu *et al.* (2015), a value of 1 was given for waters  
334 with a bad chemical water quality class. This assignment covered all the 5 WWTPs of the  
335 Regi Lagni system. Finally, the environmental impact of the WWTPs cluster, represented  
336 with  $I_{5C}$  indicator, was calculated as the average value of the impact produced by each  
337 WWTPs.

338

#### 339 2.2.2 Scenarios for future upgrading's

340 As explained later, following the assessment of the *status quo* of the Regi Lagni system,  
341 various technological solutions for the enhancement of the 5 WWTPs were considered. For  
342 this purpose, two alternative scenarios (clusters) were identified (Tab. 4).

343

#### 344 **Table 4. Scenario analysis of upgrading project actions.**

345

346 The first scenario concerned the Regi Lagni system in its current configuration (Cluster A).  
347 The second scenario (Cluster B) provided for the recovery of all treatment units for each  
348 WWTP, considering both the water and sludge lines. The scenario therefore focused on the  
349 role of anaerobic sludge digestion; the dewatered sludge, after being stored on a common

350 platform, was sent to landfill.

351 Instead, the third scenario (Cluster C) implemented the same operations as in the scenario  
352 B. Differently, the construction of a centralized thermal treatment plant for the dewatered  
353 sludge was also planned; the sludge output from the five WWTPs was thus sent to the  
354 thermal treatment plant located (virtually) in the Area Casertana WWTP. As can be seen  
355 from Table 2, a sludge incineration plant, although not functioning, was already realized at  
356 the Area Casertana site. In addition, for the third scenario, in order to calculate the GHG  
357 emissions due to transport, a standard distance of 5 km was assumed between each WWTP  
358 and the virtual thermal treatment plant. The consumption of fuel (methane gas) for  
359 incineration was estimated at 0.58 Nm<sup>3</sup> per kg of dry sludge (Mininni *et al.*, 2004), having  
360 assumed a dry content in the sludge of 30%.

361 Scenarios B and C involved the restoration of anaerobic digestion, which represents the  
362 most advantageous solution for high loaded WWTP equipped with primary sedimentation  
363 (generally, it is adopted for capacities greater than 50,000 PE). The adoption of a thermal  
364 process for scenario C was linked to the need to minimize the sludge to be disposed of in  
365 landfills, thus containing disposal costs as well as recovering energy from the combustion  
366 of sludge. These solutions were in line with literature (Panepinto *et al.*, 2016).

367

### 368 2.2.3 Multi-criteria analysis methodology

369 The two scenarios described above constituted the 2 alternatives in the context of the  
370 multi-criteria problem (De Gisi *et al.*, 2017, 2014b), whose goal was to identify the best  
371 solution.

372 The multi-criteria analysis provided for the definition of 5 indicators as previously reported  
373 (I<sub>1C</sub>-I<sub>5C</sub>).

374 The preference index, indicated with PI and defined as the parameter that aggregates the



375 information of the evaluation criteria (or indicators), was the result of the following  
376 relation (Sabia *et al.*, 2016):

377

$$PI_i = \sum_{j=1}^m \bar{x}_{ij} = \sum_{j=1}^m x_{ij} \cdot w_j \quad (2)$$

378

379 Where,  $x_{ij}$  is the performance of the alternative  $i$ -th (i.e., each cluster) with respect to the  $j$ -  
380 th evaluation criterion ( $I_{1C}$ - $I_{5C}$ ). Instead, the normalized value was calculated with the  
381 following relations:

382

$$\bar{x}_{ij} = x_{ij}/\text{Max}(x_j) \quad (3)$$

$$\bar{x}_{ij} = \text{Min}(x_j)/x_{ij} \quad (4)$$

383

384 Where, the selection of the relation depends on the nature of the criterion, if it was to  
385 maximize or minimize in respect to the general goal (to select the best scenario). In the  
386 specific case, all criteria were to be minimized.

387 The method described above allowed to evaluate the single cluster in respect of the five  
388 criteria described above and, further, to identify the best suitable cluster, representing by  
389 the scenario with the highest value of PI.

390 In order to verify the goodness of the obtained solution, three different weighing vectors  
391 were considered, corresponding to three different decision makers: environmentalist, water  
392 service operator/manager, balanced. The environmental decision-maker (Env) was the one  
393 who attached the greatest importance to pro-environmental criteria; the following  
394 condition was defined: Impact on the water body ( $I_{5C}$ ) = GHG emissions ( $I_{2C}$ ) > Wastes for  
395 landfilling ( $I_{3C}$ ) = Energy balance ( $I_{1C}$ ) > Running costs ( $I_{4C}$ ). On the other hand, the

396 decision-maker in the water service (Ser) was the one who attached the greatest importance  
397 to the pro-management criteria; the following condition was therefore defined: Running  
398 costs ( $I_{4C}$ ) = Impact on water body ( $I_{5C}$ ) > Wastes for landfilling ( $I_{3C}$ ) = Energy balance  
399 ( $I_{1C}$ ) > GHG emissions ( $I_{2C}$ ). Finally, the balanced decision-maker (Bal) was what he  
400 considered the 5 indicators to be equally important.

401 The application of the SAW-PCT (Simple Additive Weighting - Paired Comparison  
402 technique) method reported in De Gisi *et al.* (2014b) made it possible to determine, with  
403 reference to criteria  $I_{1C}$ ,  $I_{2C}$ ,  $I_{3C}$ ,  $I_{4C}$  and  $I_{5C}$ , respectively, the following weights:  $V_{Env} =$   
404 (0.167; 0.167; 0.067; 0.300; 0.300);  $V_{Ser} =$  (0.167; 0.167; 0.300; 0.067; 0.300);  $V_{Bal} =$   
405 (0.200; 0.200; 0.200; 0.200; 0.200).

406

### 407 **3. RESULTS AND DISCUSSION**

408

#### 409 *3.1 Cluster performance in current configuration*

410 Assessing the performance of the cluster in its current configuration initially included a  
411 detailed assessment of the performance of each WWTP.

412 Results in terms of BOD<sub>5</sub>, TSS and TN removal showed diverging values (Tab. 5); a total  
413 of 4 out of 5 plants did not comply with the discharge limit values (25 mg/l) for BOD<sub>5</sub>. As  
414 well as, with reference to the TN, the output values were on average higher than the set  
415 limit (15 mg/l). In addition, Napoli Nord and Area Casertana WWTPs also showed  
416 overruns in TSS, highlighting difficulties in the solid/liquid separation of secondary  
417 sedimentation. Only the Area Nolana WWTP showed excellent performance with  
418 reference to all the considered parameters.

419 The results in terms of performance were essentially in line with the technological level  
420 and operating status of the UoPs of the WWTPs (Tab. 2).

421

422 **Table 5. Main pollutants removal efficiency and comparison with the Italian legal**  
423 **limits (re-elaborated Pica *et al.*, 2016) <sup>(a)</sup>.**

424

425 The good performance of Area Nolana WWTP was the result of the upgrading actions  
426 carried out in the past years and reported in detail in Pica *et al.* (2012). The other plants,  
427 although operated by the same operator, were not subject to an adjustment.

428 The experience described in Pica *et al.* (2012) in Area Nolana WWTP allowed to explain  
429 the difficulties encountered during the upgrading of the plant; adaptation made necessary  
430 to tackle an increase in the inlet organic load (BOD<sub>5</sub>) or to comply with the new stringent  
431 limits for nitrogen compounds. The adaptation had to be carried out in such a way as to  
432 avoid interruption of the treatment service. The procedure implemented by ENEA (Italian  
433 National Agency for New Technologies, Energy and Sustainable Economic Development)  
434 and here briefly described, had initially provided for storage of the inlet wastewater  
435 (approximately 3000 m<sup>3</sup>/h) for a sufficient time to perform the work of interconnection of  
436 the new biological line with the existing operating lines. Subsequently, the new  
437 denitrification, nitrification/oxidation unit was realized and an additional secondary  
438 sedimentation unit was activated. The most arduous part of the work involved the  
439 construction of connecting pipes between the secondary sedimentation tank and the  
440 existing splitter (location of the sludge recirculation pumps) without interruption of  
441 operation. The large tubing (700mm diameter) had required the construction of a special  
442 metal carpentry that had allowed the tubing coming from secondary sedimentation to reach  
443 the central part of the existing splitter; in this way, the hydraulic load of the side wells of  
444 the aerated mixture was discharged into the metal carpentry. Pica *et al.* (2012) also pointed  
445 out how the implemented procedure resulted in only about 0.65% increase in the total cost

446 of the revamping project. The above procedure was successfully applied to Area Nolana  
447 WWTP only, although it could also be extended to the other WWTPs of the Regi Lagni  
448 system.

449 The experience described above, in addition to showing why Area Nolana worked, had  
450 highlighted how large centralized WWTPs could show a limited resilience; the upgrading  
451 of the plant, only for adaptation to the increasing inlet organic load, could be difficult to  
452 implement in the hypothesis of ensuring the continuity of service operation.

453 The subsequent analyses (costs, energy, etc.) confirmed the results of the treatment yields,  
454 although other interesting aspects were highlighted.

455

456 **Table 6. Running costs, energy consumption, GHG emissions and waste produced by**  
457 **the Regi Lagni WWTPs system on annual basis.**

458

459 The analysis of running costs, for example, made it possible to identify the unusual  
460 behaviour of Foce Regi Lagni WWTP (Tab. 6). The per capita value of 21.8 €/PE/y was  
461 symptomatic: the plant had a higher value when PE increased, thus not respecting the laws  
462 of economy of scale (Lubello and Breschi, 2000). Nevertheless, running costs were  
463 substantially in line with the literature related to large WWTPs, where Kampet (2000)  
464 referred to a per capita cost in the range of 20-30 €/PE/y for plants with a potential >  
465 100,000 PE.

466 The study of the individual cost items (Fig. 2a-f) showed that for Foce Regi Lagni and  
467 Napoli Nord WWTPs, the largest item concerned the disposal of sludge, with a percentage  
468 value of 51 and 44%, respectively. These values were wide-ranging the 34% reported in  
469 Campanelli *et al.* (2013). However, for the other plants, the main items were the cost of  
470 reagents (25% for Acerra WWTP and 27% for Area Nolana) and of the operational staff

471 (28% for Area Casertana WWTP); there was basically a good balance between costs. The  
472 operational staff of Area Casertana WWTP was in line with 27% reported in Campanelli *et*  
473 *al.* (2013).

474

475 **Figure 2. (a-f) Costs; (g-l) Energy consumption per Unit of Process (UoP); (m-r) GHG**  
476 **emissions. In the figure, (a, g, m) = Napoli Nord WWTP; (b-h-n) = Acerra WWTP;**  
477 **(c-i-o) = Area Nolana WWTP; (d-j-p) = Foce Regi Lagni WWTP; (e-k-q) = Area**  
478 **Casertana WWTP.**

479

480 The energy consumption analysis showed values in line with the economy of scale (Tab.  
481 6), with variable values in the range 12.3-58.1 kWh/PE/y. The specific consumption of  
482 Foce Regi Lagni and Area Casertana WWTPs were lower compared to those reported in  
483 literature; in this respect, the Federal Environmental Agency (2007) reported 32 kWh/PE/y  
484 for PE > 100,000, while Thöle (2008) and Haberken *et al.* (2008) showed a range of 20-42  
485 kWh/PE/y and 25-80 kWh/PE/y, respectively. Acerra and Area Nolana WWTPs were in  
486 line with the aforementioned literature.

487 The items that mostly contributed to total energy consumption were oxidation (57-76%),  
488 initial lifting (11-14%) and lifting of the return activated sludge (4-5%) (Fig. 2g-l). The  
489 Area Nolana WWTP was the only one with an energy consumption related to nitrogen  
490 removal processes, in line with the technological status shown in Table 2. In addition, it  
491 (Area Nolana) showed a much lower percentage of energy consumption (57%) due to the  
492 oxidation of the carbon fraction compared to other plants; moreover, this percentage was in  
493 line with Menendez *et al.* (2010), which reported a value of 60%.

494 The assessment of GHG emissions focused on other interesting aspects. Firstly, the low  
495 Table 6 values of GHG were broadly linked to biological treatment; the latter was

496 incomplete (i.e., not-well managed) and consequently the GHG was lower than in the case  
497 of complete treatment (Yoshida *et al.*, 2014). The detailed analysis showed that the  
498 malfunctioning plants (i.e., Foce Regi Lagni and Napoli Nord WWTPs) were characterised  
499 by high percentages of GHG emissions due to CH<sub>4</sub> and NO<sub>2</sub> from untreated wastewater.  
500 Instead, with reference to the most performing plants (i.e., Area Nolana WWTP), the  
501 higher GHG emissions were due to the production of energy to be used in the water line  
502 (71-78%), to indirect GHG emissions (10-14%) and to GHG emissions for the  
503 management of sludge (8-10%).

504 Finally, the study of the per capita production of wastes destined for disposal also revealed  
505 the anomalous behaviour of Foce Regi Lagni WWTP (Tab. 6); the per capita value (54  
506 kg/PE/y) was far greater than that of the other plants (23 kg/PE/y). Most probably, this was  
507 due to the treatment cycle implemented, based exclusively on gravity thickening and  
508 mechanical dewatering, the latter not perfectly efficient. With regard to the Napoli Nord  
509 WWTP, the sludge production was substantially in line with De Feo *et al.* (2012);  
510 assuming a specific production of 50 kg/PE/y, there was a per capita sludge production of  
511 51 kg/PE/y.

512 The above results made it possible to quantify the I<sub>1C</sub>-I<sub>5C</sub> indicators, thus extending the  
513 evaluation on a cluster scale. Results showed current cost values (I<sub>1C</sub>), energy consumption  
514 (I<sub>2C</sub>), GHG emissions (I<sub>3C</sub>) and landfill waste production (I<sub>4C</sub>) of 18.8 €/PE, 24.7 kWh/PE,  
515 113.5 kgCO<sub>2,eq</sub>/PE and 33.1 kg/PE, respectively (See cluster A, Fig. 3).

516

517 **Figure 3. (a) Running costs, (b) energy consumption, (c) GHG emissions, (d) wastes**  
518 **for landfilling and (e) environmental impact on the water body for the clusters under**  
519 **investigation. Cluster A = Scenario composed by the 5 WWTPs that implement the**  
520 **current technologies (status quo); Cluster B = Scenario subject to structural and**

521 **technological upgrading with sludge management by anaerobic digestion; Cluster C =**  
522 **As in the case of the scenario B, but with a sludge-fired centralized thermal plant,**  
523 **which treats the dewatered sludge of all 5 WWTPs.**

524

525 As far as waste is concerned, it was found to be composed of screening waste, sands, oils  
526 & greases and dewatered sludge. Stored in suitable areas, they were destined for landfill  
527 disposal, jointly managed by the unique operator (Fig. 4).

528

529 **Figure 4. Mass balance of waste generated by each WWTP and by the Regi Lagni**  
530 **system as a whole in the current configuration (Cluster A).**

531

532 In terms of impact on the receiving water body, the  $I_{5C}$  indicator, calculated as the average  
533 value of impacts on the water body of each WWTP, showed a value of 0.839. Such a high  
534 value was largely attributable to the low treatment yields of the main polluting parameters  
535 such as BOD<sub>5</sub>, TSS and TN, as shown previously. In particular, among all the plants,  
536 Napoli Nord WWTP contributed mostly (Fig. 5).

537

538 **Figure 5. Impact on the receiving water body of the 5 WWTPs and of the cluster.**

539

540 The analysis of the cluster in its initial configuration was subsequently used to compare the  
541 goodness of the WWTPs upgrading hypotheses, as herein described.

542

543 *3.2 Cluster performance in future configurations following plant upgrading*

544 Two alternative scenarios were considered. The first would have provided for the recovery  
545 of all UoPs and the putting into operation of anaerobic digestion, for all facilities of the

546 system. The second, in addition to the contents of the previous scenario, would also have  
547 provided for the construction of a centralized thermal treatment plant for the treatment of  
548 the dewatered sludge produced by the Regi Lagni WWTPs, thereby minimising the  
549 transport of sludge to landfill. In this respect, previous Figure 3 showed the simulation  
550 results for both scenarios.

551 It was possible to observe how all the indicators, with the exception of GHG emissions  
552 ( $I_{3C}$ ), showed an increase with respect to the *status quo*; bringing the plants to comply with  
553 the legal limits, there was inevitably an increase in running costs, energy consumption and  
554 wastes for landfilling.

555 The multi-criteria evaluation, whose theoretical bases are given in section 2.2.3, allowed to  
556 identify the best scenario, that was the one based on the upgrading of plants by the  
557 operation of anaerobic digestion of sludge (Fig. 6a).

558

559 **Figure 6. Preference Index score for the identification of the best management**  
560 **scenario (cluster) varying decision-makers: Considering (a) the GHG emissions**  
561 **estimated with ECAM 2.0, (b) a further reduction in GHG emissions of 50%.**

562

563 The scenario in question was the best from a multi-criteria point of view, despite the  
564 presence of a thermal treatment plant that could have allowed to minimize the sludge to be  
565 sent to landfill. The result thus obtained was validated by varying the weights to be  
566 attributed to the criteria, and considering, therefore, three different types of decision-maker  
567 (De Gisi *et al.*, 2014a).

568 The multi-criteria evaluation carried out by imposing a reduction of the GHG emissions of  
569 50% in cluster C showed greater competitiveness of the thermal-based scenario. In  
570 particular, the “so cleaner” cluster C was the best solution for both the environmental and



571 the water service operator decision-maker. Such a higher preference index was linked to a  
572 50% reduction in GHG emissions as well as a reduction in running costs, estimated at  
573 around 30%; the latter was the result of lower consumption of methane as additional fuel.  
574 In this respect, Mininni *et al.* (2004) showed how the replacement of the traditional  
575 incineration, based on the fluidised bed technology (which is the one implemented in  
576 ECAM 2.0), with one able to integrate evaporation and fluidised bed technology (the so  
577 called integrated fluidised bed technology) allowed to obtain a drastic reduction of fuel  
578 consumption and as a consequence, also the GHG emissions linked to this aspect would be  
579 reduced.

580

#### 581 **4. CONCLUSIONS**

582

583 The analysis of the Regi Lagni case study, that is to say of the system of large plants built  
584 in the 70's and according to a vision that favoured large centralized WWTPs, showed a  
585 limited resilience of the plants with respect to the plant adaptations; such adaptations were  
586 necessary for various reasons as dealing with increases in the inlet organic load or the  
587 compliance with new discharge limit values, as in the case of nitrogen compounds. From  
588 the five considered plants, only Area Nolana WWTP, which was previously adapted to  
589 meet the increase in its influential organic load, demonstrated any problems in complying  
590 with the legal limit values. However, the lack of resilience, required the use of special  
591 engineering solutions; the concept was to adapt the plant without interrupting operation.

592 The case study also highlighted the importance of adopting suitable approaches for  
593 adapting the WWTPs cluster; a multi-criteria approach, able to take into account the  
594 economic, energy, GHG emissions, waste production as well as the impact on the  
595 receiving water body, was a very reliable tool. In this specific case, the cluster based on the

596 re-functioning of anaerobic digestion for all the plants represented the best solution from a  
597 multi-criteria point of view, positioning it more successfully than in the case of the  
598 scenario based on the construction of a centralised sludge thermal treatment plant.

599 Although the results obtained cannot be extended to the case of other WWTPs clusters  
600 around the world, they can be used as a reference in all similar situations, characterized by  
601 the presence of a cluster of large WWTPs interconnected (i.e., in sludge management), a  
602 single water service operator as well as the need to adapt the plants since they have  
603 reached the end of their life cycle.

604

#### 605 **ACKNOWLEDGEMENTS**

606

607 The authors express their gratitude to Giuseppe Iannone for the valuable support he has  
608 shown during the processing of the results. In addition, the authors thank the anonymous  
609 reviewers for their comments, which have strengthened the article.

610

#### 611 **DECLARATION OF INTEREST**

612

613 None

614

#### 615 **REFERENCES**

616

617 ARPAC, 2010. Classification of the water bodies of the Campania Region (Southern Italy)  
618 in quality classes in accordance with the Water Framework Directive for 2010 (Available  
619 on line at this link: <http://www.arpacampania.it/riepilogo-acque-superficiali>; Accessed on  
620 7 June 2018).

621

622 Brown, V., Jakson, D.W., Khalifé, M., 2010. 2009 Melbourne metropolitan sewerage  
623 strategy: a portfolio of decentralised and on-site concept designs. *Water Sci. Technol.*  
624 62(3), 510-517.

625

626 Campanelli, M., Foladori, P., Vaccari, M., 2013. Electrical consumption and energy  
627 efficiency in waste water treatment. Maggioli Editore, pp. 386 (in Italian).

628

629 Crites, R.W., Tchobanoglous, G., 1998. Small and Decentralized Wastewater Management  
630 Systems. MacGraw-Hill, New York, USA.

631

632 De Feo, G., De Gisi, S., Ferrara, C., Notarnicola, M., 2017. Comparison between the waste  
633 management of two Southern Italy Regions: Lessons learnt and future perspectives. In  
634 Proceedings Sardinia 2017/Sixteenth International Waste Management and Landfill  
635 Symposium/ 2 - 6 October 2017 S. Margherita di Pula, Cagliari, Italy.

636

637 De Feo G., De Gisi S., Galasso M., 2012. Wastewater. Design and management of  
638 treatment and disposal facilities, Dario Flaccovio Editore Srl, Palermo, Italy, pp. 1244 (in  
639 Italian).

640

641 De Feo, G., De Gisi, S., Ferrante, A., Galasso, M., De Rosa, R., Giuliani, A.,  
642 Guadagnuolo, S., Pucci, L., 2009. The first year of operation of the Nocera Superiore  
643 waste-water treatment plant. *IA Ingegneria Ambientale* 37(6), 310-317 (in Italian).

644

645 De Gisi, S., Molino, A., Notarnicola, M., 2017. Enhancing the recovery of gypsum in

646 limestone-based wet flue gas desulfurization with high energy ball milling process: A  
647 feasibility study. *Process Saf. Environ.* 109, 117-129.

648

649 De Gisi, S., Casella, P., Notarnicola, M., Farina, R., 2016. Grey water in buildings: a mini-  
650 review of guidelines, technologies and case studies. *Civ. Eng. Environ. Syst.* 33(1), 35-54.

651

652 De Gisi, S., Sabia, G., Casella, P., Farina, R., 2015. An integrated approach for monitoring  
653 efficiency and investments of activated sludge-based wastewater treatment plants at large  
654 spatial scale. *Sci. Total Environ.* 523, 201-218.

655

656 De Gisi, S., Petta, L., Wendland, C., 2014a. History and technology of Terra Preta  
657 Sanitation, *Sustainability* 6(3), 1328-1345.

658

659 De Gisi, S., Petta, L., Farina, R., De Feo, G., 2014b. Development and application of a  
660 planning support tool in the municipal wastewater sector: The case study of Italy. *Land  
661 Use Policy* 41, 260-273.

662

663 Dürrenmatt, D.J., Wanner, O., 2014. A mathematical model to predict the effect of heat  
664 recovery on the wastewater temperature in sewers. *Water Res.* 48, 548-558.

665

666 EC, 2000. Directive 2000/60/EC of the European Parliament and of the Council of 23  
667 October 2000 establishing a framework for Community action in the field of water policy.  
668 Official J Eur Union, L327/1.

669

670 ECAM 2.0 Manual – Draft V1 August 2017. Energy Performance and Carbon Emissions

671 Assessment and Monitoring Tool Methodology (Available at this link:  
672 [http://wacclim.org/wp-content/uploads/2017/08/ECAM-V2-Methodology\\_Aug2017.pdf](http://wacclim.org/wp-content/uploads/2017/08/ECAM-V2-Methodology_Aug2017.pdf);  
673 Accessed on 7 June 2018).

674

675 ENEA, Capacità prestazionali dei depuratori afferenti al sistema idrico dei Regi Lagni,  
676 2010a (Available at this link: [http://www.bologna.enea.it/ambtd/regi-](http://www.bologna.enea.it/ambtd/regi-lagni/Regi_Lagni_up-to-date_2010/)  
677 [lagni/Regi\\_Lagni\\_up-to-date\\_2010/](http://www.bologna.enea.it/ambtd/regi-lagni/Regi_Lagni_up-to-date_2010/)) (Accessed on 3 March 2018) (in Italian).

678

679 ENEA, Progetto Regi Lagni, 2010b (Available at this link:  
680 <http://eboals.bologna.enea.it/ambtd/regi-lagni/homepage-rl.html>) (Accessed on 3 March  
681 2018) (in Italian).

682

683 D.Lgs. 152/2006. Decreto Legislativo 3 aprile 2006, n. 152. “Norme in materia  
684 ambientale”, Gazzetta Ufficiale n. 88 del 14 aprile 2006 – Supplemento Ordinario n. 96 (in  
685 Italian).

686

687 Federal Environmental Agency (Umweltbundesamt), 2007. Electricity consumption of  
688 WWTP's at German.

689

690 Haberkern, B., Maier, W., Schneider, U., 2008. Steigerung der Energieeffizienz auf  
691 kommunalen Kläranlagen (Enhancing the energy efficiency of municipal wastewater  
692 treatment plants) Dessau-Roßlau (Germany): Umweltbundesamt.

693

694 International Water Association (IWA) specialist group on design, operation and costs of  
695 large wastewater treatment plants (Available at this link: <http://www.iwa->

696 network.org/groups/design-operation-and-costs-of-large-wastewater-treatment-plants/)  
697 (Accessed on 3 March 2018).  
698  
699 Jung, Y.T., Narayanan, N.C., Cheng, Y.-L., 2018. Cost comparison of centralized and  
700 decentralized wastewater management systems using optimization model. *J. Environ.*  
701 *Manage.* 213, 90-97.  
702  
703 Kampet, T. (2000), The cost planning for building, operating and maintaining wastewater  
704 treatment plants. Presentation in the frame of the Tacis Project: “Water environmental  
705 monitoring and management in the Kaliningrad Oblast”. MVV/Innotec. (Available at this  
706 link: [https://cgi.tu-harburg.de/~awwwweb/wbt/emwater/documents/lesson\\_c2.pdf](https://cgi.tu-harburg.de/~awwwweb/wbt/emwater/documents/lesson_c2.pdf))  
707 (Accessed on 3 March 2018).  
708  
709 Lazarova, V., Hills, S., Birks, R., 2003. Using recycled water for non-potable, urban uses:  
710 a review with particular reference to toilet flushing. *Water Sci. Technol.* 3, 69-77.  
711  
712 Lee, E.J., Criddle, C.S., Geza, M., Cath, T.Y., Freyberg, D.L., 2018. Decision support  
713 toolkit for integrated analysis and design of reclaimed water infrastructure. *Water Res.* 134,  
714 234-252.  
715  
716 Libralato, G., Volpi Ghirardini, A., Avezzi, F., 2012. To centralise or to decentralise: An  
717 overview of the most recent trends in wastewater treatment management. *J. Environ.*  
718 *Manage.* 94, 61-68.  
719  
720 Lubello, C., Breschi, T., 2000. Benchmarking of water services: wastewater treatment

721 plants. Edizioni Suggest, Roma, Italy (in Italian).  
722  
723 Massoud, M.A., Tarhini, A., Nasr, J.A., 2009. Decentralized approaches to wastewater  
724 treatment and management: applicability in developing countries. *J. Environ. Manage.* 90,  
725 652-659.  
726  
727 McCann, B., June 2010. Exploiting wastewater potential through nutrient recovery  
728 research. *Water* 21, 39-41.  
729  
730 Menendez, M., 2010. How we use energy at wastewater plants...and how we can use less.  
731 Conference of the North Carolina Section of the American Water Works Association,  
732 Charlotte, NC.  
733  
734 Metcalf & Eddy, 2003. Wastewater engineering. Treatment and Reuse (4th ed.), McGraw  
735 Hill, New York.  
736  
737 Mininni, G., Braguglia, C.M., Passino, R., Tomei M.C., 2004. A comprehensive strategy  
738 for sludge management. In the proceedings of the National Conference Ecomondo 2004, 3-  
739 6 November, Rimini, Italy (in Italian).  
740  
741 Panepinto, D., Fiore, S., Genon, G., Acri, M., 2016. Thermal valorization of sewer sludge:  
742 Perspectives for large wastewater treatment plants. *J. Clean. Prod.* 137, 1323-1329.  
743  
744 Pica, R., Giuliano, A., Sabia, G., Busi, S., De Gisi, S., 2016. The remediation of the Regi  
745 Lagni system in Campania. Problems in the operation of wastewater treatment networks in

746 critical contexts. In proceedings of the National Conference Ecomondo 2016, 8-11  
747 November, Rimini, Italy.

748

749 Pica, R., Pasanisi, F., Tebano, C., Salluzzo, A., Cesaro, G., 2012. Regi Lagni: Revamping  
750 of the Wastewater Treatment Plant “Area Nolana” Without Service Interruption. *Energia,*  
751 *Ambiente e Innovazione* 4-5, 115-122 (Available at this link:  
752 <http://www.enea.it/it/seguici/pubblicazioni/EAI/anno-2012/n.-4-5-luglio-ottobre-parte->  
753 [I/regi-lagni-revamping-of-the-wastewater-treatment-plant-201carea-nolana201d-without-](http://www.enea.it/it/seguici/pubblicazioni/EAI/anno-2012/n.-4-5-luglio-ottobre-parte-)  
754 [service-interruption](http://www.enea.it/it/seguici/pubblicazioni/EAI/anno-2012/n.-4-5-luglio-ottobre-parte-)) (Accessed on 3 March 2018).

755

756 Sabia, G., De Gisi, S., Farina, R., 2016. Implementing a composite indicator approach for  
757 prioritizing activated sludge-based wastewater treatment plants at large spatial scale. *Ecol.*  
758 *Indic.* 71, 1-18.

759

760 Teodosiu, C., Robu, B., Cojocariu, C., Barjoveanu, G., 2015. Environmental impact and  
761 risk quantification based on selected water quality indicators. *Nat. Hazards* 75 (1), 89-105.

762

763 Thöle, D., 2008. Ways to identify possibilities of energy saving at wastewater treatment  
764 plants. Water and Energy Workshop, IWA World Water Congress 2008, Vienna, 9  
765 September 2008.

766

767 WaCCliM project, Waste and Wastewater Companies for Climate Mitigation (Available at  
768 this link: <http://wacclim.org/ecam-tool/>) (Accessed on 3 March 2018).

769

770 Weber, B., Cornel, P., Wagner, M., 2007. Semi-centralised supply and treatment systems



771 for (fast growing) urban areas. *Water Sci. Technol.* 55(1-2), 349-56.

772


773 Wilderer, P.A., Schreff, D., 2000. Decentralised and centralised wastewater management:

774 a challenge for developers. *Water Sci. Technol.* 41, 1-8.


775

776 Yoshida, H., Mønster, J., Scheutz, C., 2014. Plant-integrated measurement of greenhouse


777 gas emissions from a municipal wastewater treatment plant. *Water Res.* 61, 108-118.




**Figure 1.** The anthropic basin of the Regi Lagni system: (a) Hydrographic sub-basins; (b) Main river and the 5 large WWTPs.




**Figure 2.** (a-f) Costs; (g-l) Energy consumption per Unit of Process (UoP); (m-r) GHG emissions. In the figure, (a, g, m) = Napoli Nord WWTP; (b-h-n) = Acerra WWTP; (c-i-o) = Area Nolana WWTP; (d-j-p) = Foce Regi Lagni WWTP; (e-k-q) = Area Casertana WWTP.




**Figure 3.** (a) Running costs, (b) energy consumption, (c) GHG emissions, (d) wastes for landfilling and (e) environmental impact on the water body for the clusters under investigation. Cluster A = Scenario composed by the 5 WWTPs that implement the current technologies (*status quo*); Cluster B = Scenario subject to structural and technological upgrading with sludge management by anaerobic digestion; Cluster C = As in the case of the scenario B, but with a sludge-fired centralized thermal plant, which treats the dewatered sludge of all 5 WWTPs.



**Figure 4.** Mass balance of waste generated by each WWTP and by the Regi Lagni system as a whole in the current configuration (Cluster A).



**Figure 5.** Impact on the receiving water body of the 5 WWTPs and of the cluster.



**Figure 6.** Preference Index score for the identification of the best management scenario (cluster) varying decision-makers: Considering (a) the GHG emissions estimated with ECAM 2.0, (b) a further reduction in GHG emissions of 50%.

**Table 1.** The “Regi Lagni” system wastewater treatment plants (re-elaborated Pica *et al.*, 2016).

| Parameter   | Unit                   | WWTPs       |          |             |                 |                |
|---|------------------------|-------------|----------|-------------|-----------------|----------------|
|   |                        | Napoli Nord | Acerra   | Area Nolana | Foce Regi Lagni | Area Casertana |
| PE <sub>des</sub> <sup>(a)</sup>                    | -                      | 886,000     | 828,000  | 311,000     | 632,000         | 800,000        |
| PE <sub>eff</sub> <sup>(b)</sup>                    | -                      | 227,400     | 252,400  | 406,000     | 500,000         | 850,000        |
| PE <sub>eff</sub> /PE <sub>des</sub> <sup>(c)</sup> | %                      | 25.7        | 30.5     | 130.5       | 79.1            | 106.3          |
| Average rate <sup>(d)</sup>                         | flow m <sup>3</sup> /d | 64,602.7    | 48,986.3 | 84,164.4    | 105,369.8       | 150,575.3      |
| BOD <sub>5</sub>                                    | g/m <sup>3</sup>       | 211.2       | 309.1    | 289.4       | 284.7           | 338.7          |
| TSS   | g/m <sup>3</sup>       | 458         | 175      | 204         | 117             | 184            |
| Total Nitrogen                                      | g/m <sup>3</sup>       | 45.7        | 82.4     | 67.5        | 75.9            | 73.4           |
| BOD <sub>5</sub> /NH <sub>4</sub> -N                | adim                   | 4.62        | 3.75     | 4.28        | 3.75            | 4.61           |
| Propensity to removal nitrogen <sup>(e)</sup>       | -                      | medium      | poor     | medium      | poor            | medium         |

<sup>(a)</sup>: PE<sub>des</sub> = population equivalent related to the project configuration; <sup>(b)</sup>: PE<sub>eff</sub> = population equivalent effectively served by the WWTP; where PE = corresponds to a five-day biodegradable organic load of 60 g BOD<sub>5</sub>/d; <sup>(c)</sup>: Plant load percentage; <sup>(d)</sup>: Flow rates were measured; <sup>(e)</sup>: The ratio expresses the capacity to remove nitrogen by means of a biological process (i.e., activated sludge, as in our case). According to De Feo *et al.* (2012), based on the value of the BOD<sub>5</sub>/N-NH<sub>4</sub> ration, the following classes can be used: < 4 (poor), 4-6 (medium), 6-8 (good), > 8 (excellent).



**Table 2.** Treatment schemes and status of the unit of process (UoP) (re-elaborated Pica *et al.*, 2016).

| Unit of process                      | WWTPs <sup>(a)</sup> |          |             |                 |                |
|--------------------------------------|----------------------|----------|-------------|-----------------|----------------|
|                                      | Napoli Nord          | Acerra   | Area Nolana | Foce Regi Lagni | Area Casertana |
| <b>Water line</b>                    |                      |          |             |                 |                |
| Initial pumping                      | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Screening                            | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Sand removal                         | (yes; 😞)             | (yes; 😞) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Oils removal                         | (yes; 😞)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😞)       |
| Primary sedimentation                | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Pre-denitrification                  | (no)                 | (no)     | (yes; 😊)    | (no)            | (no)           |
| Oxidation                            | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Secondary sedimentation              | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Filtration                           | (no)                 | (no)     | (yes; 😊)    | (no)            | (no)           |
| Disinfection                         | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| <b>Sludge line</b>                   |                      |          |             |                 |                |
| Pre-thickening                       | (yes; 😊)             | (yes; 😊) | (yes; 😞)    | (yes; 😊)        | (yes; 😊)       |
| Aerobic stabilization                | (no)                 | (no)     | (no)        | (no)            | (no)           |
| Anaerobic Digestion (AD)             | (yes; 😞)             | (yes; 😞) | (yes; 😞)    | (yes; 😞)        | (yes; 😊)       |
| Post-thickening                      | (yes; 😞)             | (no)     | (yes; 😊)    | (no)            | (yes; 😊)       |
| Sludge chemical conditioning         | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Mechanical dewatering                | (yes; 😊)             | (yes; 😊) | (yes; 😊)    | (yes; 😊)        | (yes; 😊)       |
| Thermal drying/incineration          | (no)                 | (no)     | (no)        | (no)            | (yes; 😞)       |
| Engine energy production from biogas | (yes; 😞)             | (yes; 😞) | (yes; 😞)    | (yes; 😞)        | (yes; 😊)       |

<sup>(a)</sup>: In the round brackets: yes = the unit of process is available, no = otherwise; UoP status: 😊 = works well; 😞 = not well managed; 😞 = does not work.

**Table 3.** Input data availability for the evaluation of the current cluster.

| Input data                  | Unit               | WWTPs <sup>(a,b)</sup> |             |              |                 |                |
|-----------------------------|--------------------|------------------------|-------------|--------------|-----------------|----------------|
|                             |                    | Napoli Nord            | Acerra      | Area Nolana  | Foce Regi Lagni | Area Casertana |
| Electricity consumption     | kWh/m <sup>3</sup> | (yes; 0.56)            | (no)        | (yes; 0.48)  | (yes; 0.16)     | (yes; 0.22)    |
| Dewatered sludge production | kg/m <sup>3</sup>  | (yes; 0.56)            | (yes; 0.32) | (yes; 0.16)  | (no)            | (yes; 0.30)    |
| Sand production             | kg/m <sup>3</sup>  | (yes; ~0)              | (yes; ~0)   | (yes; 0.125) | (yes; 0.04)     | (yes; 0.015)   |
| Biogas production           | m <sup>3</sup> /d  | (yes; ~0)              | (yes; ~0)   | (yes; ~0)    | (yes; ~0)       | (yes; 838.7)   |
| Persons employed            | Person             | (yes; 68)              | (yes; 47)   | (yes; 48)    | (yes; 69)       | (yes; 84)      |
| Running costs               | €/m <sup>3</sup>   | (no)                   | (no)        | (no)         | (no)            | (no)           |

<sup>(a)</sup>: In the round brackets: yes = yes, the data is provided by the WWTP operator; no = otherwise, the data was estimated; <sup>(b)</sup>: The number in brackets is the value of the data provided by the WWTP operator.

**Table 4.** Scenario analysis of upgrading project actions.

| N. | Scenario/Cluster   | Concerned WWTPs  | Characteristics of the interventions   |  |
|----|--|--|--|--|
|    |  |  | Water line   | Sludge line  |
| A  | Current configuration. Anaerobic digestion not working.                      | -  | -  | -  |
| B  | Upgrading based on Anaerobic Digestion.                                      | Acerra, Foce Regi Lagni, Napoli Nord, Area Nolana.                 | Recovering of all UoPs; Pre-denitrification; Oxidation/nitrification well managed. | Recovering of all UoPs; Anaerobic digestion well managed; Mechanical dewatering well managed; Energy recovery from biogas.                               |
| C  | As in the case of the previous scenario, but with a thermal treatment plant. | Acerra, Foce Regi Lagni, Napoli Nord, Area Nolana, Area Casertana. | As in the previous scenario.   | As in the previous scenario; Realization of a centralized waste-to-energy plant for the incineration of sledges produced by the Regi Lagni system WWTPs. |

**Table 5.** Main pollutants removal efficiency and comparison with the Italian legal limits (re-elaborated Pica *et al.*, 2016) <sup>(a)</sup>.

| Parameter          | Unit             | LVs <sup>(b)</sup> | WWTPs <sup>(c)</sup> |           |             |                 |                |
|--------------------|------------------|--------------------|----------------------|-----------|-------------|-----------------|----------------|
|                    |                  |                    | Napoli Nord          | Acerra    | Area Nolana | Foce Regi Lagni | Area Casertana |
| BOD <sub>5</sub>   | g/m <sup>3</sup> | 25                 | (33.8; ☹)            | (34.0; ☹) | (20.2; ☺)   | (45.6; ☹)       | (50.8; ☹)      |
| TSS                | g/m <sup>3</sup> | 35                 | (87.0; ☹)            | (21.0; ☺) | (24.5; ☺)   | (32.7; ☺)       | (40.4; ☹)      |
| TN <sup>(d)</sup>  | g/m <sup>3</sup> | 15                 | (38.4)               | (15.6)    | (13.5)      | (60.7)          | (38.2)         |
| %BOD <sub>5</sub>  | %                | ≥80                | (84.0; ☺)            | (89.0; ☺) | (93.0; ☺)   | (84.0; ☺)       | (85.0; ☺)      |
| % TSS              | %                | ≥90                | (81.0; ☹)            | (88.0; ☺) | (88.0; ☹)   | (72.0; ☹)       | (78.0; ☹)      |
| %TN <sup>(d)</sup> | %                | 70-80              | (16.0)               | (81.0)    | (80.0)      | (20.0)          | (47.9)         |

<sup>(a)</sup>: Average values considering the year of observation; <sup>(b)</sup>: Limits refer to plants with capacity > 100,000 PE; <sup>(c)</sup>: In the round brackets: the value; ☺ = compliance with the discharge limit value of the D.Lgs 152/2006; ☹ = not in compliance; <sup>(d)</sup>: the WWTPs under investigation discharge into a non-sensitive area; therefore, they are not subject to the nitrogen limit value.

**Table 6.** Running costs, energy consumption, GHG emissions and waste produced by each WWTP of the Regi Lagni WWTPs system on annual basis.

| N. | WWTP            | PE <sub>eff</sub> <sup>(a)</sup> | Running costs |        | Energy consumption          |          | GHG emissions         |                           | Wastes for landfilling <sup>(b)</sup> |         |
|----|-----------------|----------------------------------|---------------|--------|-----------------------------|----------|-----------------------|---------------------------|---------------------------------------|---------|
|    |                 |                                  | [€]           | [€/PE] | [kWh]                       | [kWh/PE] | [t <sub>CO2eq</sub> ] | [kg <sub>CO2eq</sub> /PE] | [t]                                   | [kg/PE] |
| 1  | Napoli Nord     | 227,400                          | 6,622,869.9   | 29.1   | 13,204,800.0                | 58.1     | 29,358.0              | 129.1                     | 13,454.9                              | 59.0    |
| 2  | Acerra          | 252,400                          | 4,641,822.1   | 18.4   | 8,940,000.0                 | 35.4     | 32,585.0              | 129.1                     | 5,999.2                               | 24.0    |
| 3  | Area Nolana     | 406,000                          | 7,136,448.2   | 17.6   | 14,745,600.0                | 36.3     | 39,901.0              | 98.3                      | 9,201.8                               | 23.0    |
| 4  | Foce Regi Lagni | 500,000                          | 10,887,889.3  | 21.8   | 6,153,600.0                 | 12.3     | 64,550.0              | 129.1                     | 27,088.4                              | 54.0    |
| 5  | Area Casertana  | 850,000                          | 12,730,086.8  | 15.0   | 12,091,200.0 <sup>(c)</sup> | 14.2     | 87,455.0              | 102.9                     | 18,247.4                              | 21.0    |

<sup>(a)</sup>: Population equivalent that effectively loads the plant; <sup>(b)</sup>: Wastes (solid and liquid) produced in the plant and destined for landfilling; <sup>(c)</sup>: It refers to the net value as the difference between the energy needs of the plant and the energy produced in the plant through the anaerobic digestion of sludge.